



CITY OF CALLAWAY  
POLE BARN PROJECT  
BID NO.: PW2021-17

ADDENDUM #1

Date Issued: November 18, 2021

\*\*\*\*\*

This addendum is being released to provide for the following:

1. Regarding roof panels, it mentions both standing seam and AG and PBR – please clarify which we were are use. Or can we pick our own? **The two FEMA replacement pole barns, #4 & #5 are required to have the Standing Seam. The others can be any type as long as they are at least 26 gauge.**
2. You are asking for “extra” concrete in each hole, is there a certain amount of extra you are looking for? **Please disregard the requirement for “extra” concrete.**

**ADDITIONALLY:** These pole barns will require engineered drawings that state they meet the Florida building code of at least 140 MPH winds.



Janice L. Peters, City Clerk

\*\*\*\*\*

This Addendum must be acknowledged and included with the bid packet submission.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date