



ADDENDUM #1

FOLEY SOCCER COMPLEX LIGHT REPAIRS

Requisition No. REC-111920

NOVEMBER 10, 2020

Addendum #1 with the following changes to the Foley Soccer Complex Light Repairs Bid Packet:

- Contractor must visit site and walk job with city personnel prior to bid.
- Lighting contractors shall be rated for HID Lighting – No definite purpose contractor.
- Sports lighting fixtures shall be by Hubbell Lighting.
- Light pole shall be equivalent to pole manufactured by Baldwin Pole out of Bay Minette, AL.
- Night time aiming will be required to ensure even lighting distribution.
- City understands that replacement poles and fixtures may take an extended time to arrive. All other items shall be completed within the 15 days and then the contractor may come back to replace the poles and fixtures once they arrive.

Please acknowledge receipt of Addendum #1 on page 3 of the bid packet when submitting your bid.

Rachel Keith
Project Manger
City of Foley