

Saginaw Public School District

Request For Proposals

1010 Hoyt Ave. Saginaw, MI 48607

(Formerly Ruben Daniels/Central Middle School)

Replacement of Two Heating Pumps and Corresponding Motors

Scope of Work:

Furnish labor and materials to replace heating pumps and corresponding motors (2) located in the 2nd floor Mechanical Room.

Demo and remove existing pumps and corresponding motors (2).

Install new pumps and corresponding motors (2). Manufacturer to be existing or equivalent.

Re-pipe new pumps to existing piping.

Install new valves on the inlet and outlet of the pumps.

Install new triple-duty valves.

Install new strainers.

Insulate all new piping and repair/replace any insulation damaged during project.

If at any time an unforeseen problem should arise, work should stop and be reviewed by the Contractor and Saginaw Public School District Representatives. Any additional or unexpected billable work must be approved before proceeding once contract is awarded.