

ADDENDUM NO. 1

DATE: September 4, 2018
TO: All Offerers 
FROM: Julie Smith Maxwell, Procurement Specialist
SUBJECT: Addendum No. 1 – Broadway/Magnolia Fencing
REQUEST FOR QUOTES DUE: September 7, 2018, at 2:30:00 p.m. Eastern Time

This addendum is being published to respond to questions asked by a potential offerer regarding the above-referenced Request for Quotes. This addendum becomes a part of the Contract Document and modifies the original specifications as noted.

Question 1: What are the specs for the ornamental and black chain-link fence?

Response:

1. Fence fabric shall be 6 feet in height, vinyl coated with a #9 gauge galvanized core wire.
2. End, corner, and gate posts shall be S40 vinyl coated to match the fabric and set 3 feet deep in concrete.
3. The line posts shall be 2 inch S40 pipe and vinyl coated to match the fabric set 3 feet deep in concrete
4. The fence shall have a 1 5/8 inch top rail and bracing at terminal location.
5. The fence shall have a #7 gauge galvanized bottom tension wire securely fastened to the fabric.
6. Gates shall be constructed with 2 inch vinyl coated S20 pipe.
7. Posts spacing shall not be more than 10 feet apart.

END OF ADDENDUM NO. 1