



SOLICITATION ADDENDUM

City of Leesburg | Purchasing Division
204 N. 5th Street | PO Box 4906030
Leesburg, FL 34749-6030
Phone: (352) 728-9880 | purch@leesburgflorida.gov

ADDENDUM NO.1

Date Issued: February 21, 2018

Quote: **18-0219 – Roof Replacement – 3rd Street Restroom**

The following changes are made to quote document 18-0219:

- Deleted or removed language is indicated by ~~striketrough font~~. Deleted language should not be considered by the Contractor when preparing their bid.
- Added or new language is indicated by ***bold, underline, and italic font***. This is new language that should be considered by the Contractor when preparing their bid. This added language or information is now part of the solicitation and ultimately the contract.

REVISION TO EXECUTION

2.2.12 Contractor shall replace metal caps around perimeter.

2.2.13 HVAC flashing/shroud on top of curb shall be replaced by the City in coordination with Contractor's movement of the HVAC unit.

REVISION TO SCHEDULE OF BID ITEMS

This Addendum provides a revised Schedule of Bid Items form and must be used in place of the original form when submitting your bid. A bid item has been added.

QUESTIONS AND ANSWERS

The following are answers to all questions received to date. Information shall be considered by proposers when preparing their response.

- Q1. Are there any other roofing systems or materials acceptable to the City on this project?
- A1. *No. The roofing system of the 2-ply modified bitumen roof system is the only acceptable roof system.*
- Q2. Would the City consider using metal on face of parapet?
- A2. *Yes. The Item Bid Schedule has been revised to reflect an Additive Alternate for metal on the parapet instead of roofing material.*

All other elements of the Solicitation Document remain unchanged.

Please direct any questions related to this addendum to the Purchasing Office.

ACKNOWLEDGEMENT

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response in the space provided on the Certification/Addendum Acknowledgement Form included in the original solicitation document. Failure to do so may subject the bidder to disqualification.

ITB 18-0219

****** REVISED – ADDENDUM NO. 1 ******

SCHEDULE OF BID ITEMS

Your Bid MUST BE submitted on this form. Double check the Bid prices.
 Amounts cannot be changed following the Bid due date and time.

Submitting Vendor Name: _____

ITEM NO.	ITEM DESCRIPTION	QTY	UNIT	BID AMOUNT
1	3RD STREET ROOF REPLACEMENT in accordance with the Scope of Work section of this document. Price to include all labor, equipment, materials, permits, material disposal, and supervision.	1	LS	\$
ADDITIVE OPTIONS				OPTION UNIT PRICE
AO1	PLYWOOD ROOF DECK REPLACEMENT Price per square foot to replace wood decking as needed. Unit price includes all materials, labor and equipment to replace 1 square foot of roof decking.	1	Square Feet	\$
<i><u>ADDITIVE ALTERNATE</u></i>				<i><u>ALTERNATE UNIT PRICE</u></i>
<u>AO2</u>	<i><u>METAL ON PARAPET</u></i> <i><u>This amount would be an adjustment to the base bid in Item 1. Indicate add or deduct accordingly.</u></i>	<u>1</u>	<u>LS</u>	\$ [] ADD [] DEDUCT

Time for Completion

The City desires work to be completed as soon as possible. The City must complete the roof replacement in advance of interior improvements. The interior improvements must be completed prior to the annual Bike Fest event in downtown Leesburg.

The City may take into account the start date and completion time when selecting a bidder for award.

Date you can start work: _____

Number of CALENDAR DAYS to complete the work: _____ Calendar Days

Bidders State of Florida Contractor License Number: