



ADDENDUM NO. 1

DATE: 3-13-17

TO: ALL BIDDERS

FROM: JAMES TUCKER; SENIOR BUYER; BOYCE EVANS, PURCHASING AGENT

SUBJECT: HVAC FOR ADAPTIVE CENTER

BID TO CLOSE ON: 3-16-17

This addendum becomes a part of the quote specifications and modifies the original specifications as noted.

ITEM NO. 1: Please add these changes to the specifications: The fresh air dampers are not to be installed with these units but automatic economizer dampers must be installed on each unit instead. All new ductwork associated with this new system is required to be properly insulated. The new installation must meet and pass all inspection criteria which include the installation of a smoke detection system.

ITEM NO. 2: The closing date has been changed from 3-16-17 at 2:30 pm to 3-20-17 at 2:30 pm.

END OF ADDENDUM NO. 1