



Transformers – Request for Quote (RFQ)

ADDENDUM I

Answers to Questions

1. Is a transformer specification available?
No, we only issue a brief description of the features that must be included.
2. What will the loss evaluation criteria be?
We will use a value of \$5.251 to no-load losses and \$1.313 to load losses.
3. For Item 9 (single phase, 25 kva pad-mount), Type 1 or Type 2?
Type 2 – Item 9 should indicate a single-phase 25 kva transformer for use on a 12,470GY/7,200 volts primary system, 240/120 volts secondary with 3 secondary bushings.