

BACKFLOW PREVENTION ASSEMBLY STANDARD INSTALLATION INSTRUCTIONS

- A backflow prevention assembly is considered customer plumbing. Call Water assumes no liability and makes no warranty regarding performance of any backflow prevention assembly.
- 2. Backflow prevention assembly shall be only those approved for use by the State Water Resources Control Board. Backflow prevention assembly and all piping used for potable water service must be lead free (<0.25% lead). Dedicated irrigation and fire suppression services may continue to use approved low lead components.
- 3; Any deviation from the installation specifications described herein must receive Cal Water approval prior to installation.
- 4. Backflow prevention assembly shall be installed on the consumer's property, immediately after the meter, in the orientation in which it was evaluated and approved. If backflow prevention assembly is not placed immediately after the meter, then proposed location needs to be approved by Cai Water. In addition, 4" concrete cap and/or sleeve shall be placed around the pipe connecting the meter and the assembly. Vertical clearance to finished grade and obstructions shall be between 12 and 36 inches. A minimum 18" horizontal clearance must be provided for testing and maintenance. Installation shall comply with all local ordinances regarding permits and property line setback requirements.
- 5. No outlets, tees, taps, by-pass, swing joints; or other connections, temporary or permanent, shall be installed between the water meter and the backflow prevention assembly. Pressure reducing valves and unions (not part of the backflow prevention assembly) may be installed upstream of the backflow prevention assembly; however, in no case shall there be a union located both upstream and downstream of the assembly.
- Alternate installation locations or arrangements shall be reviewed and approved by Cal Water prior to installation.
- 7. Any plumbing modification to any part of the backflow prevention assembly will render the assembly "unapproved". Unapproved assemblies will result in disruption of water service and will require replacement with an approved assembly at customer's expense.

- 8. Installation of a backflow prevention assembly creates a closed water system. Cal Water recommends installation of thermal expansion protection as required by the California Plumbing Code.
- Where necessary the backflow prevention assembly should be protected from vehicle damage.
- 10. In freeze prone areas, a protective enclosure is recommended. Enclosure must have adequate drainage in accordance with Cal Water requirements.
- 11. Water services which cannot be turned off for short durations should have backflow prevention assemblies installed in parallel.
- 12. Under no circumstances are the backflow prevention assembly's test ports be used for anything other than testing (i.e. no garden hase connections, tubing, irrigation timers, etc.)
- The relief port located at the bottom of the backflow prevention assembly must be kept free of all obstructions at all times.
- 14. It is the customer's responsibility to ensure that the backflow prevention assembly is kept in good working order at all times, to have the assembly tested annually and after repairs, according to Cal Water requirements. Fallure to perform required testing or keep the backflow prevention assembly in good working order will result in disruption of water service.
- 15. Cantact your local Cal Water office to schedule a final inspection PRIOR to backfilling any exposed piping.

 Re—excavation may be required if trenches are backfilled prior to inspection by Cal Water.

ENGINEERING	DISTRIBUTION DATE: INIT, MAP PLAT		SURE PRINCIPLE R ASSEMBLY FOR	DISTRICT: All
	SYSTEM SCHEMATIC		RGER SERVICES DESIGNED BY:	DATE:
a la	STATION STREAM		APPROVED BY: DATE:	2/10/2016 PROJECT ID.: .
DEPARTMENT	SCALE: N.T.S.	REVISION: R3. Revised to meet drafting stendards, minor corrections, modified note 2; Split & modified note 4. LP/WR 2/10/2016		DRAWING NO.: CW752 R3