

Station 1

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION BELLVIEW/ PINE FOREST
ADDRESS 7009 PINE FOREST RD
PHONE NO. 850-941-6006

INSPECTION SYSLE DATES DUE

1st 01/09/17
2nd 07/14/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 80REOZJB
SPEC NO. GM21199-GA9
SERIAL NO. 2008711

ENGINE

MAKE JOHN DEERE
MODEL NO. 4045TF250
SPEC NO. 4 CYL
SERIAL NO. PE4045T393076

TRANSFER SWITCH

MAKE KOHLER (2)
MODEL NO. KCT-AFNA-01045/4005
SPEC NO. N/A
SERIAL NO. K2008905/K2008751

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 80
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 3.5 GALLONS
ANTIFREEZE 6 GALLONS
SPARKPLUGS P/N P
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1243
FUEL FILTER P/N P 600091
FUEL LEVEL 75%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 709.3 FINISH 709.7

Sub station

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION PENSACOLA
ADDRESS BELLVIEW/MAYWOOD
PHONE NO. 850-932-3131

INSPECTION SYSLE DATES DUE

1st 01/09/17

2nd 07/14/17

3rd _____

4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ81
SPEC NO. PA-189123-81
SERIAL NO. 377251

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039DF
SPEC NO. CD4039D
SERIAL NO. 268355

TRANSFER SWITCH

MAKE PORTABLE
MODEL NO. N/A
SPEC NO. N/A
SERIAL NO. N/A

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.3 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1243
FUEL FILTER P/N P 600091
FUEL LEVEL 80%
ADDITIONAL COMMENTS: _____

INSPECTED BY. _____

HOURS: START 1203.7 FINISH 1204.0

Station 2

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION BEULAH
ADDRESS 6400 W. 9 MILE RD.
PHONE NO. 850-941-6010

INSPECTION SYSLE DATES DUE
1st 01/10/17
2nd 07/12/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ61
SPEC NO. PA-189123-61
SERIAL NO. 377262

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039DF
SPEC NO. CD4039D
SERIAL NO. 267039

TRANSEER SWITCH

MAKE KOHLER
MODEL NO. G120-164313-200
SPEC NO. N/A
SERIAL NO. K0701184

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 3
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.3 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1243
FUEL FILTER P/N P 600019
FUEL LEVEL 75%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 658.4 FINISH 658.8

Station 3

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION "W" STREET/BRENT
ADDRESS 525 N. "W" STREET
PHONE NO. 850-494-7275

INSPECTION SYSLE DATES DUE
1st 01/10/17
2nd 07/13/17
3rd _____
4th _____

GENERATOR

MAKE GENERAC
MODEL NO. 10262940200
SPEC NO. _____
SERIAL NO. 2099794

ENGINE

MAKE JOHN DEERE
MODEL NO. 4045HF285
SPEC NO. 0G2538
SERIAL NO. 4045L057779

TRANSFER SWITCH

MAKE GENERAC
MODEL NO. 10262940100
SPEC NO. 400 AMPS
SERIAL NO. 97626

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 100
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 3.8 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 7750S
FUEL FILTER P/N P 600158
FUEL FILTER P/N P 3978
FUEL LEVEL FULL
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 266.3 FINISH 266.7

Station 4

F

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION CANTONMENT
ADDRESS #2 WOODLAND AVE.
PHONE NO. 850-937-2210

INSPECTION SYSLE DATES DUE

1st 01/11/17

2nd 07/12/17

3rd _____

4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ61
SPEC NO. PA-189123-61
SERIAL NO. 377265

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039DF
SPEC NO. CD4039D
SERIAL NO. 267047

TRANSFER SWITCH

MAKE GENERAC
MODEL NO. 3029520100
SPEC NO. N/A
SERIAL NO. 82770

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.3 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSER P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1243
FUEL FILTER P/N P 600091
FUEL LEVEL 90%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 635.6 FINISH 636.0

Station 5

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION CENTURY PO BOX 990
ADDRESS 10 TEDDER RD/HWY 29
PHONE NO. 850-256-4592

INSPECTION SYSLE DATES DUE

1st 01/05/17

2nd 07/12/17

3rd _____

4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ
SPEC NO. PA-189140
SERIAL NO. 607217

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039DF004
SPEC NO. CD4039D
SERIAL NO. 377110

TRANSFER SWITCH

MAKE KOHLER
MODEL NO. K-164231-225
SPEC NO. _____
SERIAL NO. K-86428

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.5 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N D

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1243
FUEL FILTER P/N P 600091
FUEL LEVEL 65%
ADDITIONAL COMMENTS: _____

INSPECTED BY _____

HOURS: START 917.0 FINISH 917.4

Station 6

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION ENSLEY
ADDRESS 8624 PENSACOLA BLVD.
PHONE NO. 850-475-5550

INSPECTION SYSE DATES DUE

1st 01/03/17
2nd 07/13/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 125REOZJF
SPEC NO. GM72460-GA1
SERIAL NO. 3016077

ENGINE

MAKE JOHN DEERE
MODEL NO. 4045HF285
SPEC NO. _____
SERIAL NO. PE4045L180829

TRANSFER SWITCH

MAKE KOHLER
MODEL NO. KC5-DFNA-0400B
SPEC NO. _____
SERIAL NO. K3013229

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 125
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 4 GALLONS
ANTIFREEZE 3 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P
FUEL FILTER P/N P
FUEL FILTER P/N P
FUEL LEVEL 70%

INSPECTED BY: _____

HOURS: START 159.6 FINISH 160.0

Station 7

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION FERRY PASS
/ADDRESS 2331 E. JOHNSON AVE
PHONE NO. 850-477-1747

INSPECTION SYSLE DATES DUE

1st 01/05/18

2nd _____

3rd _____

4th _____

GENERATOR

MAKE KATOLIGHT
MODEL NO. D125FGJ4
SPEC NO. _____
SERIAL NO. 119368-1005

ENGINE

MAKE JOHN DEERE
MODEL NO. 6068TF250
SPEC NO. _____
SERIAL NO. PE6068T504611

TRANSFER SWITCH

MAKE ASCO
MODEL NO. H00300020600F10F
SPEC NO. N/A
SERIAL NO. 325409RE

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 125
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 5 GALLONS 15W/40
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N N SEE NOTE
OIL FILTER P/N P
FUEL FILTER P/N P
FUEL LEVEL 75%
ADDITIONAL COMMENTS: _____

INSPECTED BY: ? _____

HOURS: START 207.5 FINISH 207.9

Station 8

E

CUSTOMER ESCAMBIA FIRE DEPT.
 LOCATION INNERARITY POINT
 ADDRESS 12250 INNERARITY PT
 PHONE NO. 850-492-0544

INSPECTION SYSLE DATES DUE

1st 01/03/17

2nd 07/14/17

3rd _____

4th _____

GENERATOR

MAKE KOHLER
 MODEL NO. 30ROZJ
 SPEC NO. PA-189123-61
 SERIAL NO. 386990

ENGINE

MAKE JOHN DEERE
 MODEL NO. 4039DF
 SPEC NO. CD4039D
 SERIAL NO. 314971

TRANSFER SWITCH

MAKE KOHLER
 MODEL NO. K-164231-400
 SPEC NO. N/A
 SERIAL NO. K-73289

TOTAL SYSTEM

VOLTAGE 120/240
 PHASE 1
 KW 30
 FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.3 GALLONS
 ANTIFREEZE 5 GALLONS
 SPARKPLUGS P/N N/A
 POINTS P/N N/A
 CONDENSOR P/N N/A
 ROTOR P/N N/A
 ROTOR CAP P/N N/A
 BELTS P/N P

HOSES UPPER P/N P
 LOWER P/N P
 AIR FILTER P/N P
 OIL FILTER P/N P 1243
 FUEL FILTER P/N P 600091
 FUEL LEVEL 75%
 ADDITIONAL COMMENTS: _____

INSPECTED BY: Tom

HOURS: START 900.3 FINISH 900.7

Station 159

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION MCDAVID
ADDRESS 100 N. CENTURY BLVD
PHONE NO. 850-256-5750

INSPECTION SYSLE DATES DUE

1st 01/05/17
2nd 07/06/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ61
SPEC NO. PA-189123-61
SERIAL NO. 377257

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039DF
SPEC NO. CD4039D
SERIAL NO. 268388

TRANSFER SWITCH

MAKE GENERAC
MODEL NO. RTSE200A3
SPEC NO. N/A
SERIAL NO. 446626

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.5 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P 2404
OIL FILTER P/N P 1243
FUEL FILTER P/N P 3531
FUEL LEVEL 90%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 512.5 FINISH 512.9

Station 11

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION MYRTLE GROVE
ADDRESS 7209 LILLIAN HWY.
PHONE NO. 850-455-5411

INSPECTION SYSLE DATES DUE
1st 01/10/17
2nd 07/06/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ61
SPEC NO. PA-189123-61
SERIAL NO. 377264

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039DF
SPEC NO. CD4039D
SERIAL NO. 268359

TRANSFER SWITCH

MAKE KOHLER
MODEL NO. GLS-164233-0400
SPEC NO. N/A
SERIAL NO. K0708773

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.3 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/1 _____

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1243
FUEL FILTER P/N P 600091
FUEL LEVEL 50%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 1101.6 FINISH 1102.0

Station 12

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION MASSACHUSETTS
ADDRESS 2601 MASSACHUSETTS
PHONE NO. 850-453-7719

INSPECTION SYSLE DATES DUE
1st 01/12/17
2nd 07/14/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 200RE0ZJB4XR
SPEC NO. GM19534-GA6
SERIAL NO. 2140332

ENGINE

MAKE JOHN DEERE
MODEL NO. 6081AF001
SPEC NO. 8.1 L
SERIAL NO. RG6081A177578

TRANSFER SWITCH

MAKE KOHLER
MODEL NO. KCT-ACWA-06005
SPEC NO. KCT-ACVA-01045
SERIAL NO. K2132200/K2131189

TOTAL SYSTEM

VOLTAGE 120/208
PHASE 3
KW 200
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 7 GALLONS
ANTIFREEZE 4 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1824
FUEL FILTER P/N P 3371
FUEL FILTER P/N P 3418
FUEL LEVEL 75%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 481.3 FINISH 481.7

Station 13

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION STATION #13
ADDRESS PENSACOLA BEACH
PHONE NO. 850-475-5530

INSPECTION SYSLE DATES DUE

1st 01/05/17
2nd 07/17/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 125REOZJD
SPEC NO. GMA8076-GA1
SERIAL NO. 2261994

ENGINE

MAKE JOHN DEERE
MODEL NO. 6068HF285
SPEC NO. _____
SERIAL NO. PE6068LO93816

TRANSFER SWITCH

MAKE MANUAL SWITCH
MODEL NO. SIEMENS
SPEC NO. _____
SERIAL NO. _____

TOTAL SYSTEM

VOLTAGE 120/208
PHASE 3
KW 125
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 7.4 GALLONS
ANTIFREEZE 4 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P
FUEL FILTER P/N P
FUEL FILTER P/N P
FUEL LEVEL 25%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 218.2 FINISH 218.7

Station 14

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION PLEASANT GROVE
ADDRESS 9350 GULF BEACH HWY
PHONE NO. 850-492-3652

INSPECTION SYSLE DATES DUE

1st 01/11/17
2nd 07/06/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ61
SPEC NO. PA-189123-61
SERIAL NO. 377266

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039DF
SPEC NO. CD4039D
SERIAL NO. 267046

TRANSFER SWITCH

MAKE RONK
MODEL NO. 7406
SPEC NO. N/A
SERIAL NO. 154390

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.5 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1243
FUEL FILTER P/N P 3531
FUEL LEVEL 100%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 503.5 FINISH 503.9

Station 15

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION WALNUT HILL
ADDRESS 7760 HWY 97
PHONE NO. 850-327-4431

INSPECTION SYSLE DATES DUE

1st 01/09/17

2nd 07/12/17

3rd _____

4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ61
SPEC NO. PA-189123-61
SERIAL NO. 377260

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039DF
SPEC NO. CD4039D
SERIAL NO. 267036

TRANSFER SWITCH

MAKE GENERAC
MODEL NO. 3029520200
SPEC NO. N/A
SERIAL NO. 82771

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.5 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N N SEE NOTE
OIL FILTER P/N P
FUEL FILTER P/N P
FUEL LEVEL 100%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 536.8 FINISH 537.2

Station 16

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION WARRINGTON
ADDRESS 20 N. NAVY BLVD.
PHONE NO. 850-453-7770/7772

INSPECTION SYSLE DATES DUE
1st 01/03/17
2nd 07/13/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 60ROZJ81
SPEC NO. PA-189412-81
SERIAL NO. 359615

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039TF
SPEC NO. CD4039T
SERIAL NO. 181866

TRANSFER SWITCH

MAKE KOHLER
MODEL NO. K168341-225
SPEC NO. N/A
SERIAL NO. K57607

TOTAL SYSTEM

VOLTAGE 120/208
PHASE 3
KW 60
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 3.0 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1243
FUEL FILTER P/N P 600091
FUEL LEVEL 100%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 1003.3 FINISH 1003.7

Station 17

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION W. PENSACOLA
ADDRESS 1700 N.W. ST.
PHONE NO. 850-595-3300

INSPECTION SYSLE DATES DUE
1st 01/10/17
2nd 07/13/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ61
SPEC NO. PA-189123-61
SERIAL NO. 377261

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039D
SPEC NO. CD4039D
SERIAL NO. 263235

TRANSFER SWITCH

MAKE KOHLER
MODEL NO. GL5 164233-0400
SPEC NO. N/A
SERIAL NO. KO646986

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.3 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N P TR22495

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N P
OIL FILTER P/N P 1243
FUEL FILTER P/N P 600091
FUEL LEVEL 75%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 1102.7 FINISH 1103.1

Station 18

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION MOLINO
ADDRESS 6200 FIREHOUSE RD.
PHONE NO. 850-587-2661

INSPECTION SYSLE DATES DUE

1st 01/05/17
2nd 07/12/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 30ROZJ61
SPEC NO. PA-189123-61
SERIAL NO. 377258

ENGINE

MAKE JOHN DEERE
MODEL NO. 4039DF
SPEC NO. CD4039D
SERIAL NO. 268385

TRANSFER SWITCH

MAKE WESTINGHOUSE
MODEL NO. ATVMLD20400WSU
SPEC NO. RC280380
SERIAL NO. N/A

TOTAL SYSTEM

VOLTAGE 120/240
PHASE 1
KW 30
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY 2.5 GALLONS
ANTIFREEZE 5 GALLONS
SPARKPLUGS P/N N/A
POINTS P/N N/A
CONDENSOR P/N N/A
ROTOR P/N N/A
ROTOR CAP P/N N/A
BELTS P/N N SEE NOTE

HOSES UPPER P/N P
LOWER P/N P
AIR FILTER P/N N SEE NOTE
OIL FILTER P/N P 1243
FUEL FILTER P/N P 600091
FUEL LEVEL 100%
ADDITIONAL COMMENTS: _____

INSPECTED BY: _____

HOURS: START 947.1 FINISH 947.5

Station 19

CUSTOMER ESCAMBIA FIRE DEPT.
LOCATION STATION #19
ADDRESS PERDIDO KEY
PHONE NO. 850-475-5530

INSPECTION SYSLE DATES DUE

1st 01/10/17
2nd 07/20/17
3rd _____
4th _____

GENERATOR

MAKE KOHLER
MODEL NO. 125REOZT
SPEC NO. _____
SERIAL NO. 12006473

ENGINE

MAKE JOHN DEERE
MODEL NO. 6068
SPEC NO. HFS82DD21497
SERIAL NO. CD6068L026289

TRANSFER SWITCH

MAKE MANUAL SWITCH
MODEL NO. _____
SPEC NO. _____
SERIAL NO. _____

TOTAL SYSTEM

VOLTAGE 120/208
PHASE 3
KW 125
FUEL DIESEL

ITEMS TO BE COVERED UNDER THIS AGREEMENT

ENGINE

OIL CAPACITY	<u>7.8 GALLONS</u>	HOSES UPPER P/N	<u>P</u>
ANTIFREEZE	<u>4 GALLONS</u>	LOWER P/N	<u>P</u>
SPARKPLUGS P/N	<u>N/A</u>	AIR FILTER P/N	<u>P</u>
POINTS P/N	<u>N/A</u>	OIL FILTER P/N	<u>P</u>
CONDENSOR P/N	<u>N/A</u>	FUEL FILTER P/N	<u>P</u>
ROTOR P/N	<u>N/A</u>	FUEL FILTER P/N	<u>P</u>
ROTOR CAP P/N	<u>N/A</u>	FUEL LEVEL	<u>73%</u>
BELTS P/N	<u>P</u>	ADDITIONAL COMMENTS:	_____

INSPECTED BY: _____

HOURS: START 115.15 FINISH 115.35