

Finance Department
Fifty Raupp Blvd.
Buffalo Grove, IL 60089-2198
Phone 847-459-2500
Fax 847-459-7906

White Pine Street & Utility Project Addendum #4

TO: Prospective Respondents and Other Interested Parties

FROM: The Village of Buffalo Grove Finance Department

ISSUE DATE: November 13, 2023

SUBJECT: ADDENDUM #4

Note: This Addendum is hereby declared a part of the original bid and contract documents and in case of conflict, the provisions in the following Addendum shall govern.

The following changes and clarifications shall be made to the Bid Documents for the White Pine Street & Utility Project

Q1. Bid Opening Time Change.

A1. White Pine Street & Utility Project Bid Opening time will be 10:30 AM.

Q2. Please confirm or deny that trench backfill is paid for when installing storm or sanitary sewer replacements.

A2. Trench backfill will be paid for separately.

Q3. Will trench backfill be paid for water service pipe installation? The plans suggest these are open cut?

A3. The Contractor has the option of installing service lines via open-cut or trenchless methods. Trench backfill within the roadway or curb line is included in the cost of WATER SERVICE, TYPE K COPPER, however, trench backfill under sidewalks or driveways will be paid for separately. (See Special Provision 'Water Service, Type K Copper).

Q4. Who does the tree trimming?

A4. The Villag of Buffalo Grove has completed the trimming as part of its routine program.

Q5. Please confirm the Village will be okay with daytime "local road only" closure to through traffic, then opened up off work hours.

A5. Generally, this is permitted, however the contractor must present a daily traffic plan and still permit local traffic through the site. The resident engineer can permit or deny the arrangement at any time based upon the contractor’s ability to work with the public.

Q6. I see the pavement removal (mostly) will be thicker than the asphalt replacement. What is the plan to bring the road to subbase prior to binder and how is that paid?

A6. Aggregate Base Course, Type B Varies (See Special Provision).

Q7. If the engineer is doing the layout, can they provide the contract for a price to perform the asbuilt?

A7. Yes, if the Contractor chooses. A negotiated price would be sought out between the two parties directly.

PROSPECTIVE RESPONDENTS ARE TO ACKNOWLEDGE RECEIPT OF
ADDENDUM #4. AND SHALL INCLUDE AND NOTE THIS ADDENDUM IN
YOUR RESPONSE.

RESPONDENT: _____

SIGNED: _____ DATE: _____

TITLE : _____