

Finance Department
Fifty Raupp Blvd.
Buffalo Grove, IL 60089-2198
Phone 847-459-2500
Fax 847-459-7906

White Pine Street & Utility Project Addendum #3

TO: Prospective Respondents and Other Interested Parties

FROM: The Village of Buffalo Grove Finance Department

ISSUE DATE: November 10, 2023

SUBJECT: ADDENDUM #3

Note: This Addendum is hereby declared a part of the original bid and contract documents and in case of conflict, the provisions in the following Addendum shall govern.

The following changes and clarifications shall be made to the Bid Documents for the White Pine Street & Utility Project

Q1. Will IDOT 60/40 concrete asphalt blended recycled CA-6 be allowed for the subbase and aggregate base course material?

A1. Yes, as long as it's coming from the same source per street.

Q2. Is Recycled CA-11 acceptable for trench backfill and bedding of the pipes other than underdrain?

A2. No

Q3. Is Trench backfill paid for separately for the Watermain and Sanitary main line pipe?

A3. Yes

Q4. Would a Maintenance bond be allowed in lieu of the specified letter of credit that is called out to be posted at the end of the projects?

A4. No

PROSPECTIVE RESPONDENTS ARE TO ACKNOWLEDGE RECEIPT OF ADDENDUM #3. AND SHALL INCLUDE AND NOTE THIS ADDENDUM IN YOUR RESPONSE.

RESPONDENT: _____

SIGNED: _____ DATE: _____

TITLE : _____