

Finance Department  
Fifty Raupp Blvd.  
Buffalo Grove, IL 60089-2198  
Phone 847-459-2500  
Fax 847-459-7906

**Bernard Drive Contract 1 Project Addendum #3**

---

**TO:** Prospective Respondents and Other Interested Parties  
**FROM:** The Village of Buffalo Grove Finance Department  
**ISSUE DATE:** November 10, 2023  
**SUBJECT:** ADDENDUM #3

Note: This Addendum is hereby declared a part of the original bid and contract documents and in case of conflict, the provisions in the following Addendum shall govern.

---

The following changes and clarifications shall be made to the Bid Documents for the Bernard Drive Contract 1 Project.

Q1. The spec for class D patches (special) 4” & 5” mention both binder and surface but no table is provided in the plans for thicknesses of each. Can you please clarify if surface is required and at what thickness?

A1. 2” surface and balance is binder.

Q2. Will IDOT 60/40 concrete asphalt blended recycled CA-6 be allowed for the subbase and aggregate base course material?

A2. Yes, as long as it’s coming from the same source per street.

Q3. Is Recycled CA-11 acceptable for trench backfill and bedding of the pipes other than underdrain?

A3. No

Q4. Is Trench backfill paid for separately for the Watermain and Sanitary main line pipe?

A4. Yes

Q5. Would a Maintenance bond be allowed in lieu of the specified letter of credit that is called out to be posted at the end of the projects?

A5. No

PROSPECTIVE RESPONDENTS ARE TO ACKNOWLEDGE RECEIPT OF  
ADDENDUM #3. AND SHALL INCLUDE AND NOTE THIS ADDENDUM IN  
YOUR RESPONSE.

RESPONDENT: \_\_\_\_\_

SIGNED: \_\_\_\_\_ DATE: \_\_\_\_\_

TITLE : \_\_\_\_\_