

**ARLINGTON COUNTY, VIRGINIA
OFFICE OF THE PURCHASING AGENT
2100 CLARENDON BOULEVARD, SUITE 500
ARLINGTON, VIRGINIA 22201**

NOTICE OF AMENDMENT OF CONTRACT COVERPAGE

TO: Boland Trane Services, Inc.
30 West Watkins Mill Road
Gaithersburg, MD 20878

DATE ISSUED: October 23, 2018

CONTRACT NO: 19-045-R

CONTRACT TITLE: HVAC Products and Services

AMENDMENT NO: 5

**THIS IS A NOTICE OF CONTRACT AMENDMENT AND NOT AN ORDER. NO WORK IS AUTHORIZED UNTIL
THE VENDOR RECEIVES A VALID COUNTY PURCHASE ORDER ENCUMBERING CONTRACT FUNDS.**

The above-referenced contract is modified as described in the attached Amendment 5.

EFFECTIVE DATE: December 28, 2020

EXPIRES: September 30, 2022

RENEWALS: No Renewal Options Remaining

COMMODITY CODE(S): 96100

LIVING WAGE: N

PROFESSIONAL SERVICES: N

ATTACHMENTS:

- 1. AMENDMENT 5 TO ARLINGTON COUNTY AGREEMENT NO. 19-045-R**

EMPLOYEES NOT TO BENEFIT:

**NO COUNTY EMPLOYEE SHALL RECEIVE ANY SHARE OR BENEFIT OF THIS CONTRACT NOT AVAILABLE TO
THE GENERAL PUBLIC.**

VENDOR CONTACT: Sean Boland

TEL. NO.: (240) 306-3298

EMAIL: Sean.Boland.jr@boland.com

COUNTY CONTACT: Tsehay Lightfoot DES-FMB

TEL. NO.: (703) 228-7593

E-MAIL: tlightfoot@arlingtonva.us

ARLINGTON COUNTY, VIRGINIA

**AGREEMENT NO. 19-045-R
AMENDMENT NUMBER 5 - REVISED***

This Revised Amendment Number 5 is made on January 12, 2021 and amends the original Agreement Number 19-045-R dated October 23, 2018 ("Main Agreement") between Boland Trane Services, Inc. ("Contractor") and the County Board of Arlington County, Virginia ("County").

The County and the Contractor agree to amend the Scope of Work called for under the Main Agreement by hereby adding additional locations for HVAC equipment Services as follows:

1. Long Bridge Aquatics & Fitness Center
333 Long Bridge Drive
Arlington, Virginia 22202

The monthly price of \$5,225.00 includes all labor, supervision, equipment, and supplies necessary to carry out the work at this site.

*Arlington Economic Development
110 N. Glebe Road
Arlington, Virginia 22201

*The monthly price of \$218.00 includes all labor, supervision, equipment, and supplies necessary to carry out the work at this site.

**This Revised Amendment No. 5 voids Amendment No. 5 dated January 11, 2021, adding equipment to the Arlington Economic Development location.*

2. **REFERENCE 15. NOTICES:** Notices is hereby deleted in its entirety and replaced as follows:

15. NOTICES

Unless otherwise provided in writing, all legal notices and other communications required by this Contract are deemed to have been given when either (a) delivered in person; (b) delivered by an agent, such as a delivery service; or (c) deposited in the United States mail, postage prepaid, certified or registered and addressed as follows:

TO THE CONTRACTOR:

Sean Boland
Boland Trane Services, Inc.
30 West Watkins Mill Road
Gaithersburg, MD 20878

TO THE COUNTY:

Rami Natour, Project Officer
DES-Facilities and Maintenance Bureau
1400 N Uhle St. Suite 602

Arlington, VA 22201

AND

Sharon T. Lewis, LL.M, MPS, VCO, CPPB
Purchasing Agent
Arlington County, Virginia
2100 Clarendon Boulevard, Suite 500
Arlington, Virginia 22201

TO COUNTY MANAGER'S OFFICE (FOR PROJECT CLAIMS):

Mark Schwartz, County Manager
Arlington County, Virginia
2100 Clarendon Boulevard, Suite 318
Arlington, Virginia 22201

3. **Attachment A, HVAC Equipment Services is hereby revised to include the abovementioned location and monthly price.**
4. **Exhibit B, Arlington County Facilities Management Bureau Equipment List is hereby deleted in its entirety and replaced with the Revised Exhibit B, Arlington County Facilities Management Bureau Equipment List.**


All other terms and conditions of the Main Agreement remain in effect.

WITNESS these signatures:

THE COUNTY BOARD OF ARLINGTON

BOLAND TRANE SERVICES, INC.


COUNTY, VIRGINIA

SIGNATURE: 
DocuSigned by:
5950D4E0ACC0472...

NAME: TOMEKA PRICE

TITLE: PROCUREMENT OFFICER

DATE: 1/12/2021

SIGNATURE: 
DocuSigned by:
7E13F10A92B94E9...

NAME: SEAN BOLAND

TITLE: EXECUTIVE VICE PRESIDENT

DATE: 1/12/2021

**Attachment A, HVAC Locations for and Cost
For
Equipment Services**

LOCATION	CONTRACT TYPE	ANNUAL AMOUNT	MONTHLY AMOUNT
ARLINGTON ARTS CENTER	HVAC	21,816.00	1,818.00
ARLINGTON ARTS CENTER	WATER TREATMENT	1,248.00	104.00
ARLINGTON CHILDREN'S CENTER	HVAC	8,688.00	724.00
ARLINGTON CHILDREN'S CENTER	WATER TREATMENT	-	-
CENTRAL LIBRARY	HVAC	33,024.00	2,752.00
CENTRAL LIBRARY	WATER TREATMENT	3,948.00	329.00
CHERRYDALE LIBRARY	HVAC	6,516.00	543.00
CHERRYDALE LIBRARY	WATER TREATMENT	-	-
COURT SQUARE WEST	HVAC	77,820.00	6,485.00
COURT SQUARE WEST	WATER TREATMENT	4,488.00	374.00
QUINCY I	HVAC	7,752.00	646.00
QUINCY I	WATER TREATMENT	-	-
QUINCY II	HVAC	12,408.00	1,034.00
QUINCY II	WATER TREATMENT	-	-
QUINCY III	HVAC	6,204.00	517.00
QUINCY III	WATER TREATMENT	-	-
QUINCY IV	HVAC	7,752.00	646.00
QUINCY IV	WATER TREATMENT	-	-
DAWSON TERRACE	HVAC	7,752.00	646.00
DAWSON TERRACE	WATER TREATMENT	-	-
FIRE STATION #2	HVAC	7,140.00	595.00

LOCATION	CONTRACT TYPE	ANNUAL AMOUNT	MONTHLY AMOUNT
FIRE STATION #2	WATER TREATMENT	-	-
FIRE STATION #3	HVAC	34,680.00	2,890.00
FIRE STATION #3	WATER TREATMENT	3,780.00	315.00
FIRE STATION #4	HVAC	35,340.00	2,945.00
FIRE STATION #4	WATER TREATMENT	3,948.00	329.00
FIRE STATION #6	HVAC	23,760.00	1,980.00
FIRE STATION #6	WATER TREATMENT	-	-
FIRE STATION #8	HVAC	12,876.00	1,073.00
FIRE STATION #8	WATER TREATMENT	756.00	63.00
FIRE STATION #10 TEMP	HVAC	10,704.00	892.00
FIRE STATION #10 TEMP	WATER TREATMENT	-	-
FORT C.F. SMITH	HVAC	12,408.00	1,034.00
FORT C.F. SMITH	WATER TREATMENT	756.00	63.00
GULF BRANCH NATURE CENTER	HVAC	7,368.00	614.00
GULF BRANCH NATURE CENTER	WATER TREATMENT	756.00	63.00
LEE COMMUNITY CENTER	HVAC	6,984.00	582.00
LEE COMMUNITY CENTER	WATER TREATMENT	-	-
LUBBER RUN	HVAC	-	-
LUBBER RUN	WATER TREATMENT	-	-
MADISON CENTER	HVAC	30,504.00	2,542.00
MADISON CENTER	WATER TREATMENT	756.00	63.00
SULLIVAN HOUSE	HVAC	4,968.00	414.00
SULLIVAN HOUSE	WATER TREATMENT	756.00	63.00

LOCATION	CONTRACT TYPE	ANNUAL AMOUNT	MONTHLY AMOUNT
WESTOVER LIBRARY	HVAC	7,440.00	620.00
WESTOVER LIBRARY	WATER TREATMENT	-	-
WOODMONT CENTER	HVAC	32,520.00	2,710.00
WOODMONT CENTER	WATER TREATMENT	-	-
INDEPENDENCE CARE	HVAC	28,020.00	2,335.00
INDEPENDENCE CARE	WATER TREATMENT	-	-
THOMAS BUILDING HOMELESS SHELTER	HVAC	79,836.00	6,653.00
THOMAS BUILDING HOMELESS SHELTER	WATER TREATMENT	3,768.00	314.00
AURORA HILLS (REC CTR/LIBRARY/FIRE STATION #5)	HVAC	25,848.00	2,154.00
AURORA HILLS (REC CTR/LIBRARY/FIRE STATION #5)	WATER TREATMENT	3,636.00	303.00
BARCROFT SPORTS COMPLEX	HVAC	19,536.00	1,628.00
BARCROFT SPORTS COMPLEX	WATER TREATMENT	-	-
CARLYN CENTER	HVAC	2,724.00	227.00
CARLYN CENTER	WATER TREATMENT	648.00	54.00
METRO TUNNEL	HVAC	1,560.00	130.00
METRO TUNNEL	WATER TREATMENT	-	-
COMMUNITY RESIDENCES	HVAC	9,012.00	751.00
COMMUNITY RESIDENCES	WATER TREATMENT	648.00	54.00
PRCR	HVAC	34,416.00	2,868.00
PRCR	WATER TREATMENT	2,868.00	239.00
DPW GARAGE BAY	HVAC	3,420.00	285.00
DPW GARAGE BAY	WATER TREATMENT	-	-
EQUIPMENT DIVISION	HVAC	32,556.00	2,713.00

LOCATION	CONTRACT TYPE	ANNUAL AMOUNT	MONTHLY AMOUNT
EQUIPMENT DIVISION	WATER TREATMENT	-	-
FAIRLINGTON COMMUNITY CENTER	HVAC	21,252.00	1,771.00
FAIRLINGTON COMMUNITY CENTER	WATER TREATMENT	1,092.00	91.00
FIRE STATION #1	HVAC	3,720.00	310.00
FIRE STATION #1	WATER TREATMENT	-	-
FIRE STATION #5	HVAC	20,928.00	1,744.00
FIRE STATION #5	WATER TREATMENT	1,092.00	91.00
FIRE STATION #7	HVAC	2,172.00	181.00
FIRE STATION #7	WATER TREATMENT	-	-
FIRE STATION #9	HVAC	9,612.00	801.00
FIRE STATION #9	WATER TREATMENT	-	-
FIRE TRAINING CENTER	HVAC	11,784.00	982.00
FIRE TRAINING CENTER	WATER TREATMENT	-	-
GLEN CARLYN LIBRARY	HVAC	4,656.00	388.00
GLEN CARLYN LIBRARY	WATER TREATMENT	-	-
GUNSTON BUBBLE	HVAC	5,580.00	465.00
GUNSTON BUBBLE	WATER TREATMENT	-	-
IMPOUND LOT	HVAC	9,300.00	775.00
IMPOUND LOT	WATER TREATMENT	-	-
LONG BRANCH NATURE CENTER	HVAC	7,596.00	633.00
LONG BRANCH NATURE CENTER	WATER TREATMENT	-	-
MOTOROLA BUILDING	HVAC	6,828.00	569.00
MOTOROLA BUILDING	WATER TREATMENT	-	-

LOCATION	CONTRACT TYPE	ANNUAL AMOUNT	MONTHLY AMOUNT
TRAFFIC ENGINEERING WAREHOUSE	HVAC	3,720.00	310.00
TRAFFIC ENGINEERING WAREHOUSE	WATER TREATMENT	-	-
RESIDENTIAL PROGRAM CENTER (RPC)	HVAC	28,992.00	2,416.00
RESIDENTIAL PROGRAM CENTER (RPC)	WATER TREATMENT	1,092.00	91.00
SHIRLINGTON STATION	HVAC	4,500.00	375.00
SHIRLINGTON STATION	WATER TREATMENT	-	-
SHIRLINGTON LIBRARY/SIGNATURE THEATRE	HVAC	18,144.00	1,512.00
SHIRLINGTON LIBRARY/SIGNATURE THEATRE	WATER TREATMENT	3,744.00	312.00
SOLID WASTE/TRAFFIC DIVISION BUILDING	HVAC	12,408.00	1,034.00
SOLID WASTE/TRAFFIC DIVISION BUILDING	WATER TREATMENT	2,712.00	226.00
VEHICLE WASH	HVAC	1,560.00	130.00
VEHICLE WASH	WATER TREATMENT	-	-
WALTER REED COMMUNITY CENTER	HVAC	17,136.00	1,428.00
WALTER REED COMMUNITY CENTER	WATER TREATMENT	1,092.00	91.00
WATER/SEWER/MAINTENANCE AND WAREHOUSE	HVAC	6,984.00	582.00
WATER/SEWER/MAINTENANCE AND WAREHOUSE	WATER TREATMENT	648.00	54.00
WATER/SEWER/STREETS ADMINISTRATION	HVAC	7,140.00	595.00
WATER/SEWER/STREETS ADMINISTRATION	WATER TREATMENT	-	-
WETA BUILDING	HVAC	4,188.00	349.00
WETA BUILDING	WATER TREATMENT	1,092.00	91.00
ARLINGTON RAPID TRANSPORTATION (ART HOUSE III BLDG)	HVAC	9,456.00	788.00
ARLINGTON RAPID TRANSPORTATION (ART HOUSE III BLDG)	WATER TREATMENT	756.00	63.00
3RD STREET GROUP HOME	HVAC	1,860.00	155.00

LOCATION	CONTRACT TYPE	ANNUAL AMOUNT	MONTHLY AMOUNT
3RD STREET GROUP HOME	WATER TREATMENT	-	-
CULPEPPER	HVAC	1,860.00	155.00
CULPEPPER	WATER TREATMENT	-	-
ARLINGTON MILLS	HVAC	60,768.00	5,064.00
ARLINGTON MILLS	WATER TREATMENT	4,524.00	377.00
HEAD START BUILDING	HVAC	10,464.00	872.00
HEAD START BUILDING	WATER TREATMENT	-	-
ART LIGHT MAINTENANCE BUILDING	HVAC	14,496.00	1,208.00
ART LIGHT MAINTENANCE BUILDING	WATER TREATMENT	-	-
COURT POLICE FACILITY	HVAC	45,996.00	3,833.00
COURT POLICE FACILITY	WATER TREATMENT	1,248.00	104.00
DETENTION CENTER FACILITY	HVAC	68,820.00	5,735.00
DETENTION CENTER FACILITY	WATER TREATMENT	5,280.00	440.00
ARLINGTON RAPID TRANSPORTATION PARKING LOT	HVAC	-	-
ARLINGTON RAPID TRANSPORTATION PARKING LOT	WATER TREATMENT	-	-
TRADES CENTER PARKING GARAGE	HVAC	408.00	34.00
TRADES CENTER PARKING GARAGE	WATER TREATMENT	-	-
VEHICLE WASH STATION	HVAC	2,172.00	181.00
VEHICLE WASH STATION	WATER TREATMENT	-	-
SEQUOIA PLAZA I SEQUOIA PLAZA II SEQUOIA PLAZA III	HVAC	54,089.64	4,507.47
SEQUOIA PLAZA I SEQUOIA PLAZA II SEQUOIA PLAZA III	WATER TREATMENT	-	-
LONG BRIDGE AQUATICS & FITNESS CENTER	HVAC	62,700.00	5,225.00

LOCATION	CONTRACT TYPE	ANNUAL AMOUNT	MONTHLY AMOUNT
LONG BRIDGE AQUATICS & FITNESS CENTER	WATER TREATMENT	-	-
*ARLINGTON ECONOMIC DEVELOPMENT	HVAC	2,616.00	218.00
*ARLINGTON ECONOMIC DEVELOPMENT	WATER TREATMENT	-	-
	HVAC TOTAL:	1,197,257.64	99,771.47
	WATER TREATMENT TOTAL:	57,132.00	4,761.00
	GRAND TOTAL:	1,254,389.64	104,532.47

REVISED EXHIBIT B
ARLINGTON COUNTY FACILITIES MANAGEMENT BUREAU EQUIPMENT LIST

ARLINGTON ARTS CENTER 3550 WILSON BLVD						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Chiller	Carrier, 30GTR060-72379	2403F36912	Air-Cooled	4
2	2	Boiler	TRIANGLE, PRESTIGE-SOLO	PT008816	Mechanical room	1
3	1	Air Handler Unit	Carrier, 781897	2403F37069	AHU	12
4	1	Air Handler Unit	Carrier, 781897	2403F37070	AHU-2	12
5	2	Pump	Taco, KV2007AE2HCA569M	N/A	Heating Water	4
6	2	Pump	Taco	N/A	Chilled Water	4
7	1	Air Conditioner	Dataaire, DTCU-0232	2003-1458-A	N/A	4
8	1	Air Conditioner	Dataaire, DACU-0932	2003-1459-A	N/A	4
9	2	Air Conditioner	Dataaire, DTCU-0432	2003-1460-A, 2003-1461-A	N/A	4
10	2	Air Conditioner	Dataaire, OAPC-0432	2003-14603, 2003-14642	eeee	4
11	1	Air Conditioner	Dataaire, DAPC-0432-P	2003-1464-A	N/A	4
12	27	Fan Coil Unit	Carrier, 42VBA04D?RCYSAHY	2179958/11036	N/A	2
13	1	Cabinet Unit Heater # 29	Modine/ CW-02-58	38214103-4881	Uppel level shower room	1
14	1	Cabinet Unit Heater # 30	Modine/ CW-02-58	3821043-2943	Main level Tiffany room	1
	1	Cabinet Unit Heater # 31	Modine/ CW-02-58	382043-2940	Main level Tiffany room	1
15	1	Cabinet Unit Heater # 32	Modine/CW-02-58	*	Lowqer level stairway	1
16	1	DOMESTIC HOT WATER Heaters	CC-240A-NG	8495499086		1
17	3	Heaters Electric	N/A	N/A		1
18	5	Exhaust Fans				3
ARLINGTON CHILDREN'S CENTER 1915 NORTH UHLE STREET						
NO.	QTY	EQUIPMENT TYPLE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Heat Pump	Trane		Roof	12
2	1	Heat Pump	Trane		Roof	12
3	1	Heat Pump	Trane		Roof	12
4	1	Air Handling Unit	Trane		Inside space	12
5	1	Air Handling Unit	Trane		Inside space	12
6	1	Air Handling Unit	Trane		Inside space	12

CENTRAL LIBRARY 1015 NORTH QUINCY STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	AHU-1	Carrier, 39ED577	4031T33604	AHU-1	4
2	1	Return Fan	Carrier	N/A	RETURN FOR AHU-1, 25HP	4
3	1	AHU-2	Carrier, 39ED48	0592T35143	AHU-2	4
4	1	Return Fan	Carrier	N/A	RETURN FOR AHU-2, 20HP	4
5	1	AHU-3 w/ Condenser (4)	Carrier, 39ED11	N/A	AHU-3	4
6	2	New HRU	Diakin	N/A	1st floor by loading dock	6
7	1	Air Handling Unit	Carrier/39LC1081AB1126-R	0192T20984	2800 CFM, KITCHEN AHU'S, BELT B-31 Air filter (3) 16x25x1"	4
8	1	AHU-4	CARRIER, 11110408041	42BHB20	Auditorium	4
9	1	AHU-5	CARRIER, 11110408041	42BHB20BQ4L620	Auditorium	4
10	1	AHU-1 RF VFD	ABB, ACH501-025-4-00PA	211366		1
11	1	AHU-2 SF VFD	ABB, ACH501-050-00P2	211543	PENTHOUSE	1
12	1	AHU-3 SF VFD	ABB, ACH501-050-4-00PA	211544	PENTHOUSE	1
13	1	AHU-2 RF VFD	ABB, ACS501-020-4-00P2	211365	PENTHOUSE	1
14	6	Pump	Amtrol	N/A	AHU-1 Circulating Pump	4
15	11	Exhaust fan	N/A	N/A	ROOF FRACTIONAL HP HOOD TYPE	3
16	7	Exhaust fan	N/A	N/A	GARAGE EXHAUST FANS, BELT DRIVEN	4
17	3	Exhaust fan	N/A	N/A	ELEVATOR ROOM, WALL MOUNTED, FRACTIONAL HP	3
18	6	Chiller Modules	Arctic Chill, PWCCMV0500D4-MM	A138053212, A138053712, A138053612, A138053412, A138053512, A138053512	MODULAR CHILLER	6
19	3	Chill Water Pumps P4, P5, P6	Bell and Gossett	P4 C162351-02A31, P5 C162351-01A31, P6 C162351-03A31	N/A	4
20	3	Chill Water Pump VFD	Yaskawa, Z1000 CIMR-ZU440014FAA	N/A	For Pumps 4 5, 6	1
21	3	VFDs for pumps 7, 8, and 9	ABB/ACH550	2173604031, 2173604023, 2173604023	PENTHOUSE	1
22	3	Condenser Pumps 7, 8, and 9	B & G/ SIZE e-1510 SSFSW 9.5 3BD	C246962-03G71, C246962- 02G71, C246962- 01G73	PENTHOUSE	4
23	2	Cooling Tower Fan VFD	Yaskawa, ZIOOO ZU4A0011FAA	N/A	For Cooling Tower fans 1 & 2	1
24	1	Strainer	Thompson Strainer, Miller Leaman Inc.	8-1461	For Tower Loop	1
25	16	Cabinet Unit Heater	Reed, W1060-03	N/A	Fan Powered	1
26	9	Ceiling Unit Heater	N/A	N/A	N/A	1
27	2	Air Separator	Amtrol	N/A	N/A	1
28	2	Expansion Tank	Amtrol	N/A	N/A	1
29	1	Condensing Unit	Carrier, 38AE-014-600		AIR COOLED	4
30	1	Cooling Tower	BAC, FXT-115C	91400506 AND 91400505	PENTHOUSE ROOF, 2 CELL TOWER 2 Cleanings	4
31	1	Split System	Sanyo C2432, Trane XE800	N/A	2 TONS, COOLING ONLY	4
32	1	RAF for AHU #3	Cook, 195-CIC	4122	N/A	4
33	1	Humidifier for AHU#3	Daysteam	V21237	Inspection Months: 9, 11, 1, 3	4
34	2	Humidifier for AHU#2	Daysteam	V21234, V21214	Inspection Months: 9, 11, 1, 3	4
35	2	Humidifier for AHU#1	Daysteam	V21235, V21813	Inspection Months: 9, 11, 1, 3	4
36	5	Fan Coil Units	TRANE	N/A	Stairwell	2
CHERRYDALE LIBRARY 2190 MILITARY ROAD						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Heat Pump	Carrier, 38BQ006410	M876626	N/A	4
2	1	Air Handling Unit	Carrier, 40FS220300	A002297	N/A	4
3	1	Heat Pump	Carrier, 38BQ00641	M876623	N/A	4
4	1	Air Handling Unit	Carrier, 40FS220300	A002299	N/A	4
5	1	Heat Pump	Carrier, 38BQ006410	G914801	N/A	4
6	1	Air Handling Unit	Carrier, 40FS920300E11	E98559	N/A	4

COURT SQUARE WEST 1400 N. UHLE STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Dry Cooler/Condenser	Carrier, 38AKS016520	0702F36468	5 TH FLOOR, ECC DRY COOLER, ROOF TOP UNIT, 1HP	4
2	1	Air Handling Unit	Trane	K96809358	7TH FLOOR, 2 PIPE SYSTEM, SHP	12
3	1	Air Handling Unit	Trane, 30F03	K96B09047	6 TH FLOOR, 2HP	12
4	1	Air Handling Unit	Carrier, 39181152HA5031E	4591T20125	5TH FLOOR	12
5	1	Air Handling Unit	Trane, 030F03	K96809146	2ND FLOOR, 5HP	12
6	1	Air Handling Unit	Trane, 030F03	K96B09161)	3RD FLOOR, 5HP	12
7	1	Air Handling Unit	Trane, NUF457701030F03	K89609117	1ST FLOOR, 5HP	12
8	1	Air Handling Unit	Trane, MCCA01CK	K96A08743	1ST FLOOR, 2 PIPE SYSTEM, 311P	12
9	1	Air Handling Unit	YBK-0240004	86F6690	1/2 HP, 1ST FLOOR	12
10	1	Air Handling Unit	TRANE MCCA010	K96B09146	4th floor	12
11	1	Air Handling Unit	Worthington Corp, YBK-024000U	86F66D-9	MAIN LOBBY AHU	12
12	1	Split System	Sanyo, CCI852	4611	81 LEVEL, PHONE ROOM, SPLIT UNIT	4
13	1	Split Unit	American Standard, TWE060A30088	L073STMSH	81 LEVEL, SPLIT UNIT, FEED STORE, 3/4HP	4
14	1	Humidifier	CAREL	HUMISTEAM XPLUS	5th Fl Mech Rm Heating Season Only (Inspection Months: 9, 11, 1, 3)	4
15	2	DUCT HEATER	REDD-I, RPA	334028	5TH FLOOR MEC ROOM	1
16	1	Exhaust Fan	N/A	N/A	120V	3
17	156	Fan Coil Unit	Trane FC80301KEOAOG20AC2M	196C33004	FLOORS 1,2,3,4,5,6,7, 1HP	2
18	1	Fan Coil Unit	Worthington Corp	N/A	FAN IISVI 1.5A	2
19	1	Exhaust Fan	Greenheck	N/A	EX FAN B1, B2, B3, B4 (115V)	3
20	2	Exhaust Fan	N/A	N/A	ELEVATOR ROOM EXHAUST FAN	3
21	7	Air Handling Unit Exhaust fans	Trane, FNA2191RDDOB3E3AC1TB	N/A	RETURN FANS SERVING AHU'S 1 THROUGH 7	12
22	1	Dry Cooler	DAFC-0512	91-1595A	PENTHOUSE, MOTOR-HP, FOR 5TH FLOOR ECC AT ROOF	4
23	1	Dry Cooler	DAFC	91-1593	PENTHOUSE, FOR 5TH FLOOR ECC AT ROOF	4
24	1	Dry Cooler	DAFC-0632	91-1591A	PENTHOUSE, FOR 5TH FLOOR ECC AT ROOF	4
25	1	Heat Pump	Trane, WCD0606300BC	K471005420	PENTHOUSE, FOR 6th FLOOR AT ROOF	4
26	1	Roof Top Unit	Carrier, 38AK5016520	K471005420	PENTHOUSE, ECC MAIN A/C	4
27	1	Exhaust Fan	N/A	N/A	PENTHOUSE, BATHROOM EXHAUST FAN	3
28	2	Exhaust Fan	Trane CUBA131FAA2AOBOA2B6DE	NUE457701	PENTHOUSE	3
29	1	Exhaust Fan	N/A	N/A	PENTHOUSE	3
30	1	Cooling Tower	Evapco, AT8-79B	960505	15HP 2 Cleanings	4
31	1	Cooling Tower VFD	ABB			1
32	1	Boiler	PVI BOILER, 80WBHE100A-TP	39687002	PENTHOUSE	1
33	2	Chiller	Carrier, 30HR100D500	Q606776	PENTHOUSE 3 Summer/1 Annual	4
34	1	Exhaust Fan	N/A	N/A	PENTHOUSE	3
35	1	Unit Heater	Reznor, X1105-3	AHF3183U668	PENTHOUSE	1
36	1	Elevator Room AC	Split system		PENTHOUSE	4
37	3	Pump	Aurora, 99-08265	344A-BF	BOILER ROOM, CONDENSER, CHILL/HOT WATER CIRCULATION & STANDBY PUMP AT 1>1ECH ROOM	4
38	1	Roof Top Unit	Trane CUBA131FAA2AOBOA2BCDE	NUE457701	LOWER ROOF	4
39	1	Split System	Sanyo, KS1872	6009361	208V/1PH, INCLUDES INDOOR AND OUTDOOR SECTIONS	4
40	2	Heat Pump	Trane, TWA060C300AZ	N/A	LOWER ROOF, INCLUDES INDOOR AND OUTDOOR SECTIONS	4
41	1	Exhaust Fan	Trane, FCRA13500A1EA00A	A95M48786	LOWER ROOF, SERVES PRINT SHOP	3
42	1	5111 Floor Comp Room	Data Aire, DTGU-0332	91-1590A	N/A	4
43	1	5th Floo Telephone Room	Data Aire DAME 2-512/DAMC2.5wis	91-1594A	N/A	4
44	1	5th Floor Radio Room	Data Aire, DAGU-0632	91-1592A	N/A	4
45	1	68-7RFAC02	CARRIER, 38AK-028---5	4371F76738		4
46	1	AHU-1B	TRANE, TWE060A300BB	K424TLP54		4
47	1	AHU-8	TRANE, 39LB1152HA5031-D	4591L720125		4
48	1	AHU-Ductless Unit	MITSUBISHI			4
49	1	AHU-2	TRANE, NCCA010GAL	KB960917		4
50	1	AIR COND Ductless	SAMSUNG, AQV36JAX	F826PA0C700363P		4
51	1	AIR COND -4	MITSUBISHI	MXZ4A36NA		4
52	1	RESTROOM EXHAUST FAN	45426-M	222-ABC		3
53	1	Exhaust Fan-7	CENTER MASTE, PX163F6	PQF159401		3

QUINCY I 1425 QUINCY ST						
QTY	TYPE	MANUFACTURER	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	RTU	Trane	YCD180B3L0FA	Z41100501D	Roof	4
1	RTU	Trane	TBD	TBD	Roof	4
1	RTU	Trane	TBD	TBD	Roof	4
1	RTU	Carrier	50XZ-060	0609G11564	Roof	4
1	RTU	Carrier	TBD	TBD	Roof	4
QUINCY II 1429 QUINCY ST						
QTY	TYPE	MANUFACURER	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	RTU	Carrier	48EYD038	0701F64005	Roof	4
1	RTU	Carrier	48HJD017	0501F60464	Roof	4
1	RTU	Carrier	48EYD024	TBD	Roof	4
1	RTU	Carrier	48HJE012	4900G30424	Roof	4
1	RTU	TBD	TBD	TBD	Roof	4
1	ERV	RenewAire	TBD	TBD	Roof	4
1	Split System	TBD	TBD	TBD	TBD	4
1	Split System Indoor Unit	TBD	TBD	TBD	TBD	4
1	Split System Outdoor Unit	TBD	TBD	TBD	TBD	4
1	Split System Indoor Unit	TBD	TBD	TBD	TBD	4
QUINCY III 1435 QUINCY ST						
QTY	TYPE	MANUFACTURER	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	RTU	Carrier	48TFE012	3201G32425	Roof	4
1	RTU	Carrier	48TJF016	2201F87436	Roof	4
1	RTU	Carrier	48TJF016	3701F10986	Roof	4
1	RTU	Carrier	LGA102H2BHY	L0794750060	Roof	4
QUINCY IV 1439 N. QUINCY ST						
QTY	TYPE	MANUFACTURER	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	RTU	Carrier	48AJE025	2205F15880	Roof	4
1	RTU	Carrier	48AJE030	2205F15884	Roof	4
1	RTU	Carrier	48AJE030	2205F15881	Roof	4
1	RTU	Carrier	48AJE040	2205F15883	Roof	4
1	Split	Carrier	N/A	N/A		4
DAWSON TERRACE 2133 NORTH TAFT STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/ MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	7	VRF Cassetts	Mitsubishi	N/A	Different areas in the building	4
2	1	VRF Condenser	Mitsubishi/PURY-P72TLMU-A	58W00087	Outside Front of the building	4
3	1	Cabinet heater	Airhitt	*	First floor entrance hallway	1
4	1	Bathroom EXHAUST FAN	PVD LB252	N/A	ROOF	3
5	1	RTU	Carrier	N/A	N	4
FIRE STATION #2 4805 WILSON BLVD						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	4	Roof Top Unit	Carrier, 48HJE006-531HE	5099G20259, 5099G20260, 5099G20255, 5099G20258	Roof	4
2	1	Exhaust Fan	Carnes, VEBK21R1B1UA20SPCX	661745003	Roof	3
3	1	Exhaust Fan	Leeson, N215T34FB49B	G15015960	Roof	3

FIRE STATION #3 4100 OLD DOMINION DRIVE						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	12	Heat Pumps	Trane			
2	3	Heat Pump 10,13,7B	GEHE0241	N/A	2 Ton Ceiling Plenum Mounted	4
3	5	Heat Pump 3,11,12,20,21	GEHE0151	N/A	1.5 Ton Ceiling Plenum Mounted	4
4	1	Heat Pump 5	GEHE0481	N/A	5 Ton Ceiling Plenum Mounted	4
5	1	Heat Pump 6	GEHE0601	N/A	6 Ton Ceiling Plenum Mounted	4
6	1	Split System	38mhc18a-3	1117V14763	1.8 Ton Ceiling Plenum Mounted	4
7	1	0/S Air Heat Recovery Unit	Innovent, 5000-1C-4600-AC/HG N/A	N/A	7.5 Ton Roof Mounted	12
8	1	Evaporative Cooling Tower	BAC, FXV-L422	N/A	Rear of Bldg. 2 Cleaning Inspections	4
9	2	Boilers B1,B2	Lochinvar, KB-150	N/A	150 MBH - Mechanical Room	1
10	8	HW Unit Heater UH-A	Trane, UHS-AOB	N/A	Mechanical Room	1
11	1	HW Unit Heater UH-B	Trane, UHS-36	N/A	Mechanical Room	1
12	5	EF 1-5	Greenheck, SE-1-8-440	N/A	1/30 HP App Bay & Aux areas	3
13	2	EF 6,7	Greenheck, SP-125	N/A	Fractional HP - App Bay and Aux Areas	3
14	1	EF 8	Greenheck, GB-161-7	N/A	HP - Apparatus Bay	3
15	1	EF 9	Greenheck, SP-A510	N/A	Fractional HP - Dishwasher	3
16	1	EF 10	Greenheck, SWB-208-15	N/A	1.5 HP Hood	3
17	1	EF 11	Greenheck, Plymovent	N/A	5 HP - Vehicle Exhaust	3
18	2	EF 12, 13	Greenheck, SP-B110	N/A	Fractional HP - Storage	3
19	2	Condenser Water Pumps P1 & P2	Bell & Gossett 1-1/4BC	N/A	5 HP - Mechanical Room	4
20	2	Hot Water Pumps	Bell & Gossett PL55	N/A	2/3 HP Mechanical Room	4
21	1	Computer Room AC Unit AC 1	MMD12E+PFC014A	N/A	1.1 Ton - Comm Room	4
22	1	Electric Unit Heater	Trane UHWA-03	N/A	3 KW - Stairwell	1
23	4	Infrared heater GB1-5	Vantage CTHN-80N	N/A	80,000 BTU/hr - Engine Bay	1
24	2	Hot Water Heater	N/A	N/A	N/A	1
25	2	Hot Water Heater	N/A			1
FIRE STATION #4 3121 N 10th street						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Chiller	Tandem, W040DZW	0205-533	Penthouse Inspection Months: 5, 7, 8	4
2	1	Cooling Tower	MARLEY	4832	Roof	4
3	1	Boiler	CLEAVER BROOK, FLX	BT-9491	Penthouse	1
4	4	Pump	B&G, 185011	N/A	(2) 2 HP, (2) 5 HP	4
5	1	Air Handler Unit	BRYANT, 340AAV060080	4911A02329	Basement	6
6	1	Condenser Unit	BRYANT, 24ABB360A520	3313E01101	Lower Roof	6
7	1	Rooftop Unit	AAON, RN-013-8-0-EBOA-3F9	201209-ANGK24779	Lower Roof	6
8	1	Rooftop Unit	AAON, RQ-003-8-V-EA09-319	201209-AYGC04019	Lower Roof	6
9	1	Rooftop Unit	AAON, RQ-003-8-V-EA09-319	201209-AYGC04020	Lower Roof	6
10	1	Heat Pump	TRANE, 2TWB0018A1000AB	43514B94F	Locker Room Ceiling	6
11	1	Heat Pump - Condenser	TRANE, 2TWB0018A1000AB	43514B94F	Carport	6
12	27	Fan Coil Units	MCQUAY F-TSF-503-AAO0B-30-AS-15-ZIBI	776752020	(1) 2nd Fl, (13) 3rd Fl, (13) 4th Fl	2
13	6	Hydronic Unit Heaters	MCQUAY F-TSF-503-AAO0B-30-AS-15-ZIBI	776752020	Engine Bay - Ceiling Hung	1
14	1	Server Rm Split System	CARRIER		Basement	4
15	1	Server Rm Split - Condenser	CARRIER		Wall Mtd. - rear of Bldg.	4
16	8	Exhaust Fans	N/A	N/A	1 thru 4 Lower Roof, 5-Engine Bay Roof, 6 & 7 Upper Roof, 8-Penthouse Roof	3
17	1	DHN Heater	CAMUS DYNAMAX 100	N/A	Penthouse	1
18	1	Dehumidifier			Basement Winter Inspection	4
19	1	Hot Water Heater	N/A	N/A	N	1

FIRE STATION #6 6950 LITTLE FALLS STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	13	Exhaust Fans	Various	N/A	N/A	3
2	3	Supply Fans	Various	N/A	N/A	3
3	6	Unit Heaters	Various	N/A	N/A	1
4	5	Wall Heaters	Various	N/A	N/A	1
5	5	Infraheaters and Thermostats	Various	N/A	N/A	1
6	2	Boilers	Various	N/A	Mechanical room	1
7	2	Boilers Pumps	Taco	N/A	Mechanical room	4
8	1	Expansion Tank	BX-1	N/A	Mechanical room	1
9	2	Domestic Hot Water Heater	Various	N/A	Mechanical room	1
10	2	Water Heater Pumps	Various	N/A	Mechanical room	4
11	2	New Circulating Pumps	B&G	N/A	Mechanical room	4
12	7	Air Handling Units(AHU)	Various	N/A	N/A	4
13	7	Condensing Units	Various	N/A	N/A	4
14	23	VRV Units - Ceiling	Daikin	N/A	2nd Floor	4
15	2	VRV Units - Wall	Daikin	N/A	2nd Floor Hallway	4
16	1	Split System - 1.5 ton	Daikin	N/A	1st Floor IT Room	4
17	2	HRV 3&4	American Aldes	N/A	2nd Floor Attic	12 *need access
18	2	CU 3&4	AAON	N/A	Outside rear of building	12
19	1	VRVC-2	Daikin	N/A	Outside rear of building	4
20	2	AHU 3 & 4	AAON	N/A	2nd Floor Attic	12
21	2	BS-3 & 4	Daikin	N/A	2nd Floor Attic	4
22	1	BS-5	Daikin	N/A	2nd Floor Attic	4
FIRE STATION #8 4845 LEE HIGHWAY						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Air Handling Unit	Thermal, CP-111-8	Aug-93	3/4 HP	4
2	5	Circulator Pump	B&G Series 100	10689	IN-LINE	4
3	1	Circulator Pump	Taco	N/A	IN-LINE	4
4	1	Boiler	K-5010	7620140	GAS-FIRED	1
5	2	Heater	Reznor, XL225-3	ALG31H3N42203	CEILING HUNG	1
6	1	Heat Pump	Carrier, 50HS-036---301-	2099G43277	N/A	4
7	1	Heat Pump	Carrier, 38HDL018301	2902X29519	N/A	4
8	4	Window A/C Unit	Frigidaire	N/A	N/A	4
9	2	Exhaust Fan	4HX80A	N/A	1/4 HP	3
10	1	Exhaust Fan	Garnes, BE316D	12628	1/3 HP	3
11	1	Exhaust Fan	Dayton/4HX80A	Typical	1/4 HP	3
12	1	Hot Water Heater	N/A	N/A	N/A	1
FIRE STATION #10 Temp 1791 N. QUINN ST.						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Package Unit	HVPSA36	AH-F156615-0-2		4
2	1	Package Unit	HVPSA36	TBD		4
3	1	Split System	38MRC18A-3	1117V14763	Outdoor unit	4
4	1	Split System	Carrier		Indoor unit	4
5	1	Exhaust Fan	N/A			3
6	2	Unit Heater	N/A			1
7	1	Fujitsu	AOU45RLXFZ		LYN014163	4
8	1	Fujitsu	AOU18RLXFW1		BSP006446	4
9	6	Fujitsu	Indoor Cassettes		6	2
10	2	Hot Water Heater	N/A	N/A	N/A	1
FORT C.F. SMITH 2411 NORTH 24TH STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Boiler	Burnham, SIN9LNS-LEZ	N/A	280,000 BTU	1
2	2	Heat Pump	Carrier, A61-15 REV C	N/A	INDOOR	4
3	2	Heat Pump	Carrier, CPKE60-1B	N/A		4
4	4	Air Handler Unit	Rheem, RBHA-2400NFAA	N/A	CONDENSING UNIT	4
5	1	Condensing Unit	Rheem, RAKA-060JAZ	N/A	Different places in the building	4
6	1	Pump	B&G, 189165F10	N/A		4
7	1	Roof Top Unit	Lennox, CHA15-411-3P	5489600166		4
8	2	VRF AHUs	Trane		Barn	4
9	1	VRF Condenser	Trane	N/A	FOR COTTAGE	4
10	2	Heater	Marley electric heating/ AWH4408D	Typical	WALL ELECTRIC HEATER IN BATHROOMS	1
12	2	Condensing Unit	Carrier, 38YCC060320, 38YCC036340	2105E23854, 3804E68482	N/A	4
13	3	Exhaust Fans	we didn't find them. We only have 2 restroom exhaust fans		BACK OF BUILDING	3
14	6	Circulating Pumps	N/A	N/A		3

GULF BRANCH NATURE CENTER 3608 NORTH MILITARY ROAD						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Air Conditioner	ComfortAire	10,000btus	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
2	1	Heat Pump	Carrier/40MFO22---3	4114V11619	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
3	1	Split System	Carrier, 38HDL024311	N/A	1.5 TON	4
4	1	Split System	Carrier, 39HDL0184311	N/A	1.5 TON	4
5	1	Boiler	Weil McLain, EG-65-P1	N/A	HOT WATER	1
6	2	Pump	B&G	N/A	CIRCULATING	4
LEE COMMUNITY CENTER 5722 LEE HIGHWAY						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Roof Top Unit	York, D2CG189N24025ECE	(S)NHJM107880	Roof	4
2	1	Roof Top Unit	York, DM150N20P2AAA1A	NHJM204002	Roof	4
3	1	Roof Top Unit	York, D2CG300N32025ECA	(S)NGJM098776	Roof	4
4	4	Exhaust ran	ILG, CRBCA080DII51D2	062600M105190	Roof	3
5	1	Exhaust ran	Carnes, VEDK10J3A1UA20SPCX	710271.002	Roof	3
LUBBER RUN 300 NORTH PARK STREET						
MADISON CENTER 3829 NORTH STAFFORD STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Condensing Unit	Trane	N/A	AIR COOLED, 15 TON	4
2	1	Roof Top Unit	York, EBU182-A	N/A	3HP	4
3	4	Roof Top Unit	York, D3CE036S25	N/A	3 TON	4
4	1	Roof Top Unit	York, D3P830A06A	N/A	2.5 TON	4
5	1	Roof Top Unit	York, D2CE048A25C	N/A	4 TON	4
6	1	Air Compressor	N/A	N/A	WITH AIR DRYER	3
7	2	Roof Top Unit	Carrier, 50DJ0045	N/A	N/A	4
8	7	Exhaust rans	LC Dynafan	N/A	FROM 1130 2600 CFM	3
9	7	Exhaust Fans	Domex	N/A	FROM 1565 4350 CFM	3
10	19	Air Conditioner	Friedrich & LG	Typical	WINDOW UNITS Inspection Months: 3, 5, 7, 9	4
11	1	Air Handling Unit	Trane	N/A	N/A	4
12	1	Boiler A	Prestige Solo 399US, 05624192	09/0053359	N/A	1
13	1	Boiler B	Prestige Solo 399US, 05624192	09/0053322	N/A	1
14	1	Boiler c	Prestige Solo 399US, 05624192	09/0053330	N/A	1
15	1	Boiler D	Prestige Solo 399US, 05624192	09/0053335	N/A	1
16	1	Boiler E	Prestige Solo 399US, 05624192	09/0053325	N/A	1
17	1	Heating Pump	Paco Pump	N/A	3HP Baldor Motor	4
18	1	DHW Primary Pump	Grundfoss, UP75	2722373P1	N/A	4
19	1	DHW Secondary Pump	Bell & Gossett, PL-368	1BL003	N/A	4
SULLIVAN HOUSE 3103 9TH ROAD						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	2	Air Conditioner	Frigidair	N/A	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
2	2	Air Conditioner	Comfortair, Frigidair	N/A	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
3	2	Air Conditioner	Friedrich, GE	N/A	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
4	2	Air Conditioner	Frigidair, GE	N/A	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
5	2	Air Conditioner	Frigidair	N/A	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
6	2	Air Conditioner	Frigidair	N/A	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
7	2	Air Conditioner	Frigidair, FAC08?M7A1	JK31938894	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
8	2	Air Conditioner	Carrier, XQB123D	1205834223	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
9	3	Air Conditioner	Amanda, Friedrich	N/A	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
10	2	Air Conditioner	N/A	N/A	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4
11	1	Boiler	Weil-McLain	N/A	210 MBH INOUT, NATURAL GAS	1
12	2	Pump	B&G	102210	SEVIE HV	4
13	2	Air Conditioner	GE	N/A	WINDOW UNIT Inspection Months: 3, 5, 7, 9	4

WESTOVER LIBRARY 1644 N. MCKINLEY STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	PARALLEL VAV	TRANE, VPEF	N/A	Children's Reading Room	2
2	1	PARALLEL VAV	TRANE, VPEF	N/A	Children's Reading Room	2
3	1	PARALLEL VAV	TRANE, VPEF	N/A	Group Study	2
4	1	PARALLEL VAV	TRANE, VPEF	N/A	Lobby Corridor	2
5	1	PARALLEL VAV	TRANE, VPEF	N/A	Lobby Corridor	2
6	1	PARALLEL VAV	TRANE, VPEF	N/A	Reading Room	2
7	1	PARALLEL VAV	TRANE, VPEF	N/A	Reading Room	2
8	1	PARALLEL VAV	TRANE, VPEF	N/A	Reading Room	2
9	1	PARALLEL VAV	TRANE, VPEF	N/A	Technology	2
10	1	PARALLEL VAV	TRANE, VPEF	N/A	Library	2
11	1	PARALLEL VAV	TRANE, VPEF	N/A	Library	2
12	1	PARALLEL VAV	TRANE, VPEF	N/A	Staff Lounge	2
13	1	PARALLEL VAV	TRANE, VPEF	N/A	Staff Lounge	2
14	1	PARALLEL VAV	TRANE, VPEF	N/A	Mgt Room	2
15	1	PARALLEL VAV	TRANE, VPEF	N/A	Staff Lounge	2
16	1	Ductless Split	MITSUBISHI, PKA-A18 NHA	N/A	Network Room	4
17	1	Air Cooled Condenser MITSUBISHI, PUY-A18 NHA	MITSUBISHI/ PUY-A18 NHA	A18HAZ	ROOF/SERVES THE NETWORK TELEPHONE ROOM	4
18	1	Exhaust Fan # 11	PENN BARRYI GC-720 Z12S	N/A	Mechanical Room, EF-11	3
19	1	Exhaust Fan # 2	PENN BARRY, SX100BC	A09L274351	Mechanical/Bathroom, EF-2	3
20	1	Exhaust Fan # 1	PENN ZYPHER, 71902904	N/A	Electrical Room, EF-01	3
21	1	Exhaust Fan	PENN BARRY, FX14B	A09L266881	Roof, EF-8	3
22	1	Exhaust Fan # 9	PENN BARRY, FX08B	A09L266877	Roof, EF-9	3

WOODMONT CENTER 2422 NORTH FILMORE STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Mini Split Systems	Carrier 40QHW	2500Y401140	Basement	4
1	1	Roof Top Unit	CARRIER, 48PGNC14BD150-QQ	1910G40026	Roof/ serves the gym	12
2	1	AHU # 1	CARRIER, FE4ANB006	13184914	Ground floor/voters area	4
3	1	AHU # 2	CARRIER, FE4ANB006	1310A84910	Ground floor/voters area	4
4	1	AHU # 3	CARRIER, FE4ANB006	1310A84911	Ground floor/library	4
5	1	AHU # 4	CARRIER, FE4AN003	5009A68750	Ground floor/library	4
6	1	AHU # 5	CARRIER, FE4ANF002	1710486844	1st floor staff lounge	4
7	1	AHU # 6	CARRIER, FE4ANF003	5009A68713	1st floor conference room	4
8	1	AHU # 7	CARRIER, FE4ANF003	5009A68749	1st floor office	4
9	1	AHU # 8	CARRIER, FE4ANF003	1310A88319	1st floor library space	4
10	1	AHU # 9	CARRIER, FE4ANF002	1710A86847	1st floor library space	4
11	1	AHU # 10	CARRIER, FE4ANF003	5009A68711	1st floor training room 2	4
12	1	AHU # 11	CARRIER, FE4ANF003	5009A68714	1st floor training room 2	4
13	1	AHU # 12	CARRIER, FE4ANF003	5009A8717	Second floor	4
14	1	AHU # 13	CARRIER, FE4NB006	1310A84909	1st floor training room 1	4
15	1	AHU # 14	CARRIER, FE4NB006	1310A84904	1st floor training room 1	4
16	1	AHU # 15	CARRIER, FE4NF003	5009A68756	1st floor multipurpose room	4
17	1	AHU # 16	CARRIER, FE4AF003	5009A68756	1st floor multipurpose room	4
18	1	Heat Pump # 1	CARRIER, 25HNA960A330	101E12786	Ground floor behind the building	4
19	1	Heat Pump # 2	CARRIER, 25HNA960A0033030	1010E12777	Ground floor behind the building	4
20	1	Heat Pump # 3	CARRIER, 25HNA960A0033030	1010E12780	Ground floor behind the building	4
21	1	Heat Pump # 4	CARRIER, 25HNA936A0032030	1710E25724	Ground floor under the steps	4
22	1	Heat Pump # 5	CARRIER, 25HNA924A0032030	1710E16921	Ground floor under the steps	4
23	1	Heat Pump # 6	CARRIER, 25HNA936A0032030	1710E25723	Ground floor under the steps	4
24	1	Heat Pump # 7	CARRIER, 25HNA948A0032030	1710E25726	Ground floor under the steps	4
25	1	Heat Pump # 8	CARRIER, 25HNA948A0032030	1710E24081	Ground floor behind the building	4
26	1	Heat Pump # 9	CARRIER, 25HNA924A0032030	1710E16927	Ground floor behind the building	4
27	1	Heat Pump # 10	CARRIER, 25HNA936A0032030	1710E25719	Ground floor behind the building	4
28	1	Heat Pump # 11	CARRIER, 25HNA936A0032030	1710E25728	Ground floor behind the building	4
29	1	Heat Pump # 12	CARRIER, 25HNA936A0032030	1710E25720	Roof	4
30	1	Heat Pump # 13	CARRIER, 25HN960A0330	1010E12774	First floor outside	4
31	1	Heat Pump # 14	CARRIER, 25HN960A0330	1010E12779	First floor outside	4
32	1	Heat Pump # 15	CARRIER, 25HNA936A320	1710E25721	First floor outside	4
33	1	Heat Pump # 16	CARRIER, 25HNA936A320	1710E25725	First floor outside	4
34	1	Mini-split	SAMSUNG	N/A	1.5 Tons	4
35	1	Mini-split	SAMSUNG	N/A	1.5 Tons	4
36	1	Hot Water Heater	N/A	N/A	N/A	1

INDEPENDENCE CARE 1723 N. FAIRFAX DRIVE						
NO.	QTY	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Mini Split Systems	TBD	TBD	N/A	4
2	4	Air Handlers	TBD	TBD	ROOF	6
3	18	Fan Coils	TBD	TBD	N/A	6
4	2	Exhaust Fans	TBD	TBD	N/A	3
5	1	Rooftop Unit	VALENT		ROOF	12
6	22	Condensing Units			ROOF	4

THOMAS BUILDING - HOMELESS SHELTER 2020 14TH STREET NORTH						
NO.	QTY	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #/S
1	1	Outside Air Make up unit ERU	DAIKIN	CAH010GVGC	Third Floor Mechanical room	12
2	7	VFD PUMPS	N/A	N/A	penthouse	1
3	2	Boiler	N/A	N/A	penthouse	1
4	6	Exhaust Fans	0B18/5KH32GN140GX	typical	3 on Roof and 3 in Garage	4
5	3	Supply Fans	52702		penthouse	6
6	1	Package RTU	*	1 NO INFO	penthouse, B1 janitor's closet	4
9	2	Condensing Unit	Fujitsu/A0036CLX	typical	penthouse, for the 7th floor TI room	4
10	1	Cooling Tower	BAC/PT2-0809A-3K	U107019501 (8)	penthouse	4
11	4	Air Handlers	TRANE/FB4BNF060000AAA	TYPICAL	4th, 5th, 6th and 7th mechanical rooms	4
12	24	Fan Coil Units	FXY04/UFW1544A	TYPICAL	4th floor	2
13	37	Fan Coil Units	FXY04/UFW1544A	TYPICAL	5th floor	2
14	40	Fan Coil Units	FXY04/UFW1544A	TYPICAL	6th floor	2
15	41	Fan Coil Units	FXY03/UFW1544A	TYPICAL	7th floor	2
16	1	Blower Coils	Magic Aire/60-8HW-4-A	980139936	Cooling for Penthouse	2
17	1	Blower Coils	SE-0HU-18	64A66D-35	Fresh air and heat for the penthouse	2
18	1	MUA	GREENHECK	DGX-100-112-UR	2nd floor	12
19	8	Hot Water Heater		RU981	3rd floor Mech room/shelter	1
20	1	Domestic hot water heater	SBD65251NEA118	1547M000946	penthouse	
21	1	Lobby AHU Condenser	0396E14274	*	2nd floor roof	4
22	72	VRF Cassettes				4
23		ERU				12
24		IT Mini Split w/ 4 Indoor Units				2
AURORA HILLS (RECREATION CENTER, LIBRARY, FIRE STATION #5) 735 S. 18TH STREET						
NO.	QTY	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #/S
1	1	Rooftop Units	YCH211C3LBAA	M49102303D	Roof	4
2	1	Rooftop Units	YCH211C3HBAA	M49102302D	Roof	4
3	1	Rooftop Units	YCH241C3HBAA	M49102307D	Roof	4
4	1	Cooling Tower (BAC)	VFL-012-22G	U095808901	Roof 208-230v, 3ph	4
5	1	C.T. Pumps	MARATHON/8VM56T34F5847A	FR 56J-65	Roof - 208-230v, 3ph., 3450 rpm	4
6	1	C.T. Pumps	BALDOR	Typical	Roof - 208-230v, 3ph., 3450 rpm	4
7	1	C.T. Pumps	BALDOR	Typical	Roof - 208-230v, 3ph., 3450 rpm	4
8	1	Exhaust Fans	Greenheck G-60-D-X	97K13545	Roof - 115v., 1ph., 1a	3
9	1	Exhaust Fans	Greenheck G-95-D-X	97K13625	Roof - 115v., 1ph., 3.2a	3
10	1	Exhaust Fans	Greenheck G-60-D-X	97K13546	Roof - 115v., 1ph., 1s	3
11	1	Exhaust Fans	BDCR 20 FloAire	n/a	Roof - 115v., 1ph., 13a	3
12	1	Exhaust Fans	BDCR 20 FloAire	n/a	Roof - 115v., 1ph., 13a	3
13	1	Exhaust Fans	n/a 20 FloAire	n/a	Roof	3
14	1	Unit Heater	Airtherm	n/a	Local control, HW T651	1
15	1	Unit Heater	CLIMATEMASTER/TCH012AGC30CLS S	Typical	Ceiling - Local control, HW T651	1
16	1	Unit Heater	CLIMATEMASTER/TCH012AGC30CLS S	Typical	Ceiling - Local control, HW T651	1
17	1	Unit Heater	CLIMATEMASTER/TCH012AGC30CLS S	Typical	Ceiling - Local control, HW T651	1
18	1	Unit Heater	McQuay/CCH030CEFS	7 5B00234 06	laundry rm. - Local control, HW T651	1
19	1	Heat Pump HP-1	Ceiling Mounts	PH119879	Old FH-5, Kitchen - FHP, Inc. R-22, 38oz.	4
20	1		EM031-H2C			
21	1	Heat Pump HP-2	Ceiling Mounts	7 5800234 06	Old FH-5, Laundry Rm - McQuay R-410A	4
22	1		CCH030CEFS			
23	1	Heat Pump HP-4	Ceiling Mounts	Q10720147	Old FH-5 Control rm - Climate Master	4
24	1		TCHC012AGC30CLSS			
25	1	Heat Pump HP-5	Ceiling Mounts	97C097937	Old FH-5 Captain's Office - Climate Master	4
26	1		HS090GSSSRBGSSA			
27	1		Cabinet, floor mounts			
28	1	Heat Pump HP-21	ADIRONDACK AIR	NONE	Old FH-5, Acct. Office. - McQuay R-22	4
29	1	Heat Pump HP-22	W.WMF 2.090.E.Z.OO	AUBU055100925	Old FH-5, Storage - McQuay R-22 15.4oz.	4
30	1	Heat Pump HP-23	CWL0128EGR	7 YHO8846 01	Old FH-5, Storage - Snyder Gen. R-22 15.5oz.	4
31	1	Heat Pump HP-24A	W.WMF 2.012.E.Z.OO	AUBU055101025	Old FH-5, Lamar's Office - McQuay R-22 17.3oz.	4
32	1	Heat Pump HP-24	WMH/CWH0120MGR	7 8J05119 07	Old FH-5, Storage - Snyder Gen. R-22 15.5oz.	4

33	1	Heat Pump HP-27	WMHC1018BEHBT	669288700	Old FH-5, Air Shop - McQuay R-410A	4
34	1	Heat Pump HP-29	WMHC1012BEHBT	120900749	Old FH-5, Uniform Shop - McQuay R-410A	4
35	1	Boiler B-1	33DB0400NASSS	O10330644	Mech. Rm. Sr. Ctr. - input 400,000 btuh	1
36	1	Boiler P-1	20TV1	3381	Mech. Rm. Sr. Ctr. - 460V? 3ph. 1730rpm 1.8a.	1
37	1	Boiler P-1A	20TV1	2284	Mech. Rm. Sr. Ctr. - 460V? 3ph. 1730rpm 1.8a.	1
38	1	Boiler P-2	TRUSH/GTB-2-BB	L-02	Mech. Rm. Sr. Ctr.	1
39	1	Boiler P-3	GTB-2-BB	N/A	Mech. Rm. Sr. Ctr. - 115v. 6.6a.	1
40	1	Hot Water Heater	N/A	N/A		1
BELTS					QTY	
					3	
					4	
					3	
MONTHLY FILTERS					QTY	
					24	
					1	
					1	
					1	
					4	
					1	
					1	
BARCROFT SPORTS COMPLEX 4200 S. FOUR MILE RUN DRIVE						
NO.	QTY	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #'S
1		Power Roof Ventilator	Greenheck/G-60-D-X	TYPICAL	Roof	4
2	1	Daikin RTU	MPS040FG	FB0U170201195	Roof/serves GYM ROOM 120 *Pre-filters two changes per month and unit filters one time per month	12 Insp - Change filters on 15th of every month
3	1	Daikin RTU	MPS040FG	FB0U170201196	Roof/GYM ROOM 119 *Pre-filters two changes per month and unit filters one time per month	12 Insp - Change filters on 15th of every month
4	1	Daikin RTU	DPS012AHM	FB0U170500068	Lower Roof/ serves Boxing area	12
5	1	Daikin Split System Outdoor Unit	RZR24PVJU	A003250	1st floor IT room	4
6	1	Daikin Condenser	Daikin	*	lower roof Outside	4
7	1	Daikin AHU	Daikin	FB0U170401016	1st floor serves areobics and wight rooms	4
8	1	Exhaust Fan	DX13VSR	*	Roof	3
9	1	Exhaust Fan	BX30B	*	Roof	3
10	1	Exhaust Fan	DX12B	*	Roof	3
11	1	Exhaust Fan	DX11B	*	Roof	3
12	1	Exhaust Fan	DX11B	*	Roof	3
13	16	VAV				2
CARLYN CENTER 5711 S. 4TH STREET						
NO.	QTY	EQUIPMENT	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #'S
1	1	Boiler Triangle	Prestige Excellence	PS54659	basement	1
2	1	Condensing Carrier	24ANB136A300	1912E32417		4
3	2	B&G Series 100		Inline Circulating	1/25 Hp	4
4	1	Air Handling Unit	Carrier, FE4ANB006	1812A89953		4
METRO TUNNEL 2111 WILSON BLVD						
NO.	QTY	EQUIPMENT	MODEL NO.	SERIAL NO.	LOCaiton/REMARKS	INSPECTION #'S
1	1	AIRCOND	CARRIER	73YCB224301D	3396B41232	4

COMMUNITY RESIDENCES 1212 S. IRVING ST						
NO.	UNIT	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	WAC1	Window A/C 1 LG	LWHD1200FR	703TAXT05922	Living Room, Front Window Summer Insp Only: 3, 5, 7, 9	4
2	WAC 2	Window A/C 2 LG	LWHD1200FR	703TAF01205	Dining Room, Rear Window Summer Insp Only: 3, 5, 7, 9	4
3	WAC 3	Window A/C 3 Frigidaire	FAK104R1V	IK70921399	Office, Front ctr. Summer Insp Only: 3, 5, 7, 9	4
4	WAC 4	Window A/C 4 Goldstar	GWHD6507R	612HAZX38109	Kitchen Summer Insp Only: 3, 5, 7, 9	4
5	WAC 5	Window A/C 5 Goldstar	GWHD6507R	612HALW37872	1st Flr. S.E. Bedroom Summer Insp Only: 3, 5, 7, 9	4
6	WAC 6	Window A/C 6 Goldstar	GWHD6507R	612HAGF38015	1st Flr. Ctr. Bedroom Summer Insp Only: 3, 5, 7, 9	4
7	WAC 7	Window A/C 7 Comfortaire	RAD-61-5-E	KT220675300Y	1st Flr. S.W. Bedroom Summer Insp Only: 3, 5, 7, 9	4
8	WAC 8	Window A/C 8 Goldstar	GWHD6507R	N/A	2nd Flr. Ctr. West Bedroom Summer Insp Only: 3, 5, 7, 9	4
9	WAC 9	Window A/C 9 Goldstar	GWHD6507R	612HAXC38098	2nd Flr. S.W. Bedroom Summer Insp Only: 3, 5, 7, 9	4
10	WAC 10	Window A/C 10 Goldstar	GWHD6507R	612HAFM38099	2nd Flr. N.E. Bedroom Summer Insp Only: 3, 5, 7, 9	4
11	WAC 11	Goldstar	GWHD6507R	612HALW38112	2nd Flr. N.W. Bedroom Summer Insp Only: 3, 5, 7, 9	4
12	WAC 12	Goldstar	GWHD6507R	612HAPU38752	Attic, Front Room Summer Insp Only: 3, 5, 7, 9	4
13	WAC 13	Goldstar	GWHD6507R	612HAKA38165	Attic, Rear Room Summer Insp Only: 3, 5, 7, 9	4
14	B-1	Weil-McLean Boiler	PFG-6-SPN	550201011	Basement, Entrance in front	1
15	3	B&G Pump	106189	Series 100	Basement, Entrance in front	1
16	1	Flexcon H2 Pro Expansion Tank	HTX-90	None	Basement, Entrance in front	1

PRCR 2700 S. TAYLOR STREET						
NO.	QTY	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	AHU 1	MCCB017UAO	NONE	Upper Mech. Rm.	4
2	1	AHU-2	MCCB014UAO	K05H97603	Upper Mech. Rm.	4
3	1	AHU-3	BCHC018G2A	T04H52319	(last shop)	4
4	1	AHU-4	BCHC024G2A	(burned off)	(next to last shop)	4
5	1	AHU-5	BCHC018G2A	T04H52320	Mech. Shop	4
6	1	AHU-6	BCHC024G2A	T04H52328	Wood Shop	4
7	1	AHU-7	BCHC018G2A	T04H52327	Plumbing/Elec. Shop	4
8	1	AHU-8	BCHC018G2A	T04H52324	Paint Shop	4
9	1	AHU-9	BCHC054G2A	T04K60590	Carpentry Shop	4
10	1	AHU-10	BCHC036G2A	T04K60591	Parks Mgmt. Shop Rm. 129	4
11	1	AHU-11	BCHC054G2A	T04H52329	Landscaping Storage Rm. 131a	4
12	1	AHU-12	TRANE/BCH024A1C0A1M1F000000B04FC2EB2000B0300	TOAD26130	Park mgmt Room 130	4
13	1	MUA-1	BCHC018G2A	T04H52325	Mech. Shop Storage	4
14	1	ACU-1	PK12FK3	41A01245B	Rm. 116	4
15	1	ACU-2	PK12FK3	4ZG00196A	Rm. 207	4
16	1	ACU-3	MITSUBISHI/PAKA-A12HA7	6ZA02206A	Phone closet	4
17	1	ACCU-1	PU12EK	4ZU01708A	Rear of Bldg.	4
18	1	ACCU-2	PU12EK	56U00516C	Rear of Bldg.	4
19	1	ACCU-3	MITSUBISHI/PAKA-A12NK7	PUT-A12NKA7	Rear of Bldg.	4
20	1	Exhaust Fans	Greenheck	none	Elec. Rm. 113 (L.L.)	3
21	1	Exhaust Fans	80DB 80DB-2	00/0007901	Mech. Rm. 114	3
22	1	Exhaust Fans	120SW 12S15D	00/0010301	Control Area Rm. 100	3
23	1	Exhaust Fans	GEMINI	140	Toilet 103	3
24	1	Exhaust Fans	GEMINI	140	Toilet 106	3
25	1	Exhaust Fans	150SONH 150SONH1	00/0012902	Welding Shop	3
26	1	Exhaust Fans	GEMINI	140	Toilet 109	3
27	1	Exhaust Fans	150SONH 150SONH1	00/0012901	Paint Shop	3
28	1	Exhaust Fans	GEMINI	160	Elev. Mech. Rm. 112	3
29	1	Exhaust Fans	120SQN 120SQN-B	00/0000701	Womens Rm. 118	3
30	1	Exhaust Fans	GEMINI	160	Elev. Mech. Rm. 132	3
31	1	Exhaust Fans	GEMINI	140	H/C Toilet 133	3
32	1	Exhaust Fans	GEMINI	160	Kitchen 124	3
33	1	Exhaust Fans	80SON 80SON-B	00/0001901	Storage Rm. 233	3
34	1	Exhaust Fans	80 DB-80DB-8	00/0003101	Upper Mech. Rm. 201	3
35	1	Exhaust Fans	100 SON-100SON-B	00/0004301	Mens Rm. 209	3
36	1	Exhaust Fans	GEMINI	160	Kitchen 211	3
37	1	Exhaust Fans	150SONH 150SONH1	00/0005501	Mech. Shop Storage	3
38	1	Exhaust Fans	70SON 70SON-B	00/0006701	Landscaping Storage	3

39	1	Exhaust Fans	GEMINI	140	H/C Toilet 225	3
40	1	Exhaust Fans	GEMINI	140	Storage Rm. 111	3
41	1	Unit Heaters UH-1	UNPA 042 P4	F05H38094	Main Elec. Rm.	1
42	1	Unit Heaters UH-2	UNPA 042 P4	F05H38095	Control Rm. 100	1
43	1	Unit Heaters UH-3	FFEB0301JAAD	TO5H42460	Hall o/s Rm. 114	1
44	1	Unit Heaters UH-4	FFHB0201AAAC	TO5L58216	Stairwell	1
45	1	Unit Heaters UH-5	FFEB0301JAAD	TO5H42459	MENS ROOM #117	1
46	1	Unit Heaters UH-6	FFEB0301JAAD	TO5H42457	WOMENS RM. #118	1
47	1	Unit Heaters UH-7	FFHB0201AAAC	TO5L58215	H/C Restroom 133	1
48	1	Unit Heaters UH-8	FFHB0201AAAC	TO5H42440	H/C Restroom 225	1
49	1	Unit Heaters UH-9	FFHB0201AAAC	TO5L58217	Stairwell	1
50	1	Unit Heaters UH-10	FFEB0301JAAD	TO5H42458	MENS ROOM #209	1
51	1	Unit Heaters UH-11	FFEB0301JAAD	TO5L58214	WOMENS RM. #208	1
52	1	Unit Heaters UH-12	FFEB0301JAAD	TO5H42461	Elevator Lobby	1
53	1	Unit Heaters UH-13	FFEB0301JAAD	TO5H42461	Women's Rm. Elev. Lobby	1
54	1	Unit Heaters UH-14	FFEB0301JAAD	TO5L61889	Men's Rm. Elev. Lobby	1
55	1	Unit Heaters UH-15	FFEB0301JAAD	TO5L61890	Lower Elev. Lobby	1
56	1	Unit Heaters UH-16	UNPA 042 P4	F05H38093	Main Mech. Rm.	1
57	?	Unit Heaters UH-17	UHEC 033DACA	N/A		1
58	1	Radiator FTR-1	*	N/A	Toilet Rm. 103	1
59	1	Radiator FTR-1A	*	N/A	Toilet Rm. 106	1
60	1	Radiator FTR-2	*	N/A	Toilet Rm. 109	1
61	1	Radiator FTR-3	*	N/A	Lobby Rm. 134	1
62	1	Boiler B-1	Fulton/PHW-750	98647	1st floor mechanical room	1
63	1	Boiler B-2	Fulton/PHW-750	98645	1st floor mechanical room	1
64	1	Boiler B-3	Fulton/PHW-750	98648	1st floor mechanical room	1
65	1	Cooling Tower CT-1	VTL-079	U0414411C1		4
66	1	Pumps P-1	1510BF 7.625 2.5BB	C001918-02F50	Chiller Rm.	4
67	1	Pumps P-2	1510BF 7.625 2.5BB	C001918-01F50	Chiller Rm.	4
68	1	Pumps P-3	1510BF 9 - 2.5BB	C001920-02F50	Chiller Rm.	4
69	1	Pumps P-4	1510BF 9 - 2.5BB	C001920-01F50	Chiller Rm.	4
70	1	Pumps P-5	1510BF 8.625 2BC	C001921-01F50	Chiller Rm.	4
71	1	Pumps P-6	1510BF 8.625 2BC	C001921-02F50	Chiller Rm.	4
72	1	Pumps P-10	PL30 1BL012	F60	AHU-1	4
73	1	Pumps P-11	PL30 1BL012	F60	AHU-2	4
74	1	Pumps P-12	PL30 1BL012	F60	AHU-3	4
75	1	Pumps P-13	PL30 1BL012	F60	AHU-4	4
76	1	Pumps P-14	PL30 1BL012	F60	AHU-5	4
77	1	Pumps P-15	PL30 1BL012	F60	AHU-6	4
78	1	Pumps P-16	PL30 1BL012	F60	AHU-7	4
79	1	Pumps P-17	PL30 1BL012	F60	AHU-8	4
80	1	Pumps P-18	PL30 1BL012	F60	AHU-9	4
81	1	Pumps P-19	PL30 1BL012	F60	AHU-10	4
82	1	Pumps P-20	PL30 1BL012	F60	AHU-11	4
83	1	Pumps P-21	PL30 1BL012	F60	MAU-1	4
84	1	Refrigerant Monitor	RMWERP411D01001AD	L05H03628	Chiller Rm. Summer Insp	1
DPW GARAGE BAY 4251 S. 28TH STREET						
Radiant Heaters	UNIT	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
	UH-1		FS60 NED	10001862	Fosterix / Bay 1	1
	UH-2		FS100 NED	10002067	Fosterix / Bay 1	1
	UH-3		FS60 NED	10001864	Fosterix / Bay 1	1
	UH-4		FS60 NED	10001863	Fosterix / Bay 1	1
	UH-5		5VD63	03101000008B	Dayton / Bay 2	1
	UH-6		5VD63	060920-000013A	American Infrared / Bay 3	1
Space Heaters (Fan Powered)	?		N/A	N/A	American Infrared / Bay 5	1
	Unit		M/N	S/N	mfr./Location	1
	UH-7		PA130 A	5011011080	Modine / Bay 6	1
	UH-8		F200-E	BFK6603N33188X	Reznor / Bay 6	1
	UH-9		N/A	N/A	Reznor / Bay 8	1
	UH-10		F125-E	BFL66M4N35837X	Reznor / Bay 7	1
	UH-11		CF-60	C8530248	Sterling / Bay 7	1
Exhaust Fan	Unit		M/N	S/N	mfr./Location	
	EF-1		SVF-10EXP	1278	Basement	3

EQUIPMENT DIVISION 2701 S. TAYLOR STREET						
NO.	QTY	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Heater	Reznor			1
2	1	Exhaust Fan	Belt		Roof Mounted	6
3	1	Exhaust Fan-1	120v D.D		Roof Mounted	6
4	1	Exhaust Fan-2	480v 165BRE 8F		Roof Mounted	6
5	1	Exhaust Fan-3	120v 200BRE 8D AX-24		Roof Mounted	6
6	1	Exhaust Fan-4	120v 122DRE 8B AX-20		Roof Mounted	6
7	1	Exhaust Fan-5	120v AX-30		Roof Mounted	6
8	1	Exhaust Fan-6	480v 365BRE 8K AX-44		Roof Mounted	6
9	1	Exhaust Fan-7	120v 524BAE 8F AX-30		Roof Mounted	6
10	1	Exhaust Fan-8	120v 524BAE 8F AX-29		Roof Mounted	6
11	1	Exhaust Fan-9	120v 200BRE 8D AX-24		Roof Mounted	6
12	1	Exhaust Fan-10	120v 524BAE 8F AX-30		Roof Mounted	6
13	1	Exhaust Fan-11	120v		Roof Mounted	6
14	1	Exhaust Fan-12	480v 445BRE 8Q 2-AX-44		Roof Mounted	6
15	1	Exhaust Fan-13	480v 2-AX-47		Roof Mounted	6
16	2	Fan Power Line	M/N 245DIC 811		585 RPM, 2400 CFM, 3/4 Hp, 460 V	6
17	8	Radiant Heater	Robert Fordon Econo Ray			1
18	1	Energy Recovery Unit-Annex Air	ERP-E-04-FP-HG-TB	S/N 2267-02-0914		12
19	1	Energy Recovery Units-Annex Air	ERP-E-04-FP-HG-TB	S/N 2267-03-0914		12
20	1	Energy Recovery Units	ERP-3-12-FP-HG-TB	S/N 2267-04-0914		12
21	1	Roof Top Unit - Annex Air	ERP-E-02-FP-C-HR-AM12-TD	S/N 2267-01-0714		12
22		VRV002	DAIKIN		MAIN LOBBY	4
23		VRV003	DAIKIN		MAIN LOBBY	4
24		VRV004	DAIKIN		ROOM 122, 122A	4
25		VRV005	DAIKIN		ROOM 109A	4
26		VRV006	DAIKIN		ROOM 115 LUNCH ROOM	4
27		VRV007	DAIKIN		ROOM 118 LOCKER ROOM	4
28		VRV008	DAIKIN		ROOM 201 OPEN AREA	4
29		VRV009	DAIKIN		ROOM 201 OPEN AREA	4
30		VRV010	DAIKIN		ROOM 203, 204	4
31		VRV011	DAIKIN		ROOM 205, 207, 208	4
32		VRV012	DAIKIN		ROOM 210 and 112	4
33		VRV013	DAIKIN		ROOM 215	4
34		VRV014	DAIKIN		ROOM 215	4
35		VRV015	DAIKIN		ROOM 217	4
36		VRV016	DAIKIN		2nd FLOOR KITCHEN	4
37		VRV017	DAIKIN		ROOM 105	4
38	8	Electric heater				2

FAIRLINGTON COMMUNITY CENTER 3308 S. STAFFORD STREET						
NO.	QTY	UNIT	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Splits - X01	PKA-A18 GA	63A02076B	Rm. 126A	4
2	1	Splits - MA2	PUY-A18 NHA	74U90127C	Center ROOF, R-410A	4
3	1		Cook	143S952253-	N/A	3
4	1	VAV X03	Gemini	700	Store rm. 106	2
5	1	VAV X04	Gemini	800	Corridor o/s rm.107	2
6	1	VAV X05	Gemini	140	Corridor o/s rm.116A	2
7	1	VAV X06	Gemini	800	Corridor o/s rm.132	2
8	1	VAV X07	Gemini	700	Store rm. 129A	2
9	1	VAV X08	Gemini	500	Rm. 141	2
10	1	VAV X09	Gemini	none	Rm. 143	2
11	1	VAV X10	no access		Ceiling, Store rm. 145	2
12	1	VAV X11	165 VCRH 165VH6B	00/0003601	Roof	2
13	1	VAV X12	245 SON 245SON-B	00/0001901	Attic	2
14	1	VAV X13	245 SON 245SON-B	00/0001902	Attic	2
15	1	VAV X14	245 SON 245SON-B	00/0001903	Attic	2
16	1	VAV X15	Gemini	500	Store rm. 127A	2
17	1	VAV X16	Gemini	700	Rm. 127	2
18	1	VAV X17	Gemini	700	Rm. 140, fitness	2
19	1	VAV X18	Gemini	700	Gym, 14' 8" to ceiling	2
20	1	VAV X19	Gemini	700	Sprinkler Rm., next to Boiler rm.	2
21	1	VAV X42	Gemini	700	Boiler rm.	2
22	1	VAV X43	150 VCRH 150VH5B	143S994282	O/S Rear Wall of Kitchen	2
23	1	VAV X44	none	none	Ceiling, RM. 143	2
24	1	VAV X45	none	none	Ceiling, RM. 143	2
25	1	J01 Boiler	PNB 0501-M13	G07H00199480	input 500,000 BTUH, Filter 12x16x1	1
26	1	J02 Boiler	PNB 0501-M13	G07H00199479	input 500,000 BTUH, Filter 12x16x1	1
27	1	T01 Pumps	1510 BF 8.25 2BC	C045927-01 G70	208-230v., 20.6-19.8a.,1760rpm	4
28	1	T02 Pumps	1510 BF 8.25 2BC	C045927-02 G70		4
29	1	X02 Expansion Tank	D269V	168339	Nat'l Brd. #168339, yr. 2007	2
30	1	X20 Fan Coil	FFBB0301KAAA	T07E40679	Console, L.L. Entrance	2
31	1	X21 Fan Coil	FFBB0301KAAA	T07E40678	Console, Storage rm. 118C	2
32	1	X22 Fan Coil	FFBB0301KAAA	T07E40685	Console, Storage rm. 118D	2
33	1	X23 Fan Coil	FFBB0301KAAA	T07E40682	Console, Vestibule 130A	2
34	1	X24 Fan Coil	FFBB0301KAAA	T07E40686	Console, Restroom, Kitchen	2
35	1	X25 Fan Coil	FFBB0301KAAA	T07E40681	Console,Mech. Rm. 143	2
36	1	X26 Fan Coil	FFBB0301KAAA	T07E40683	In-wall, Vestibule 115A	2
37	1	X27 Heater	UHSB0361TAA	F07J39642	Boiler rm.	2
38	1	X28 Heater	UHSB0361TAA	F07J39643	Mezzanine Mech. Rm.	2
39	1	X29 Heater	Radiator		#1 Stairwell	2
40	1	X30 Heater	UHAAO31ATAD	None Available	O/S RESTROOM 004	2
41	1	X31 Heater	UHAAO31ATAD	N/A	O/S RESTROOM 005	2
42	1	X32 Heater	UHAAO31ATAD	N/A	Office #107A	2
43	1	X33 Heater	UHAAO31ATAD	N/A	Office #107B	2
44	1	X34 Heater	UHAAO31ATAD	N/A	Office #112	2
45	1	X35 Heater	UHAAO31ATAD	N/A	Office #113	2
46	1	X36 Heater	UHAAO31ATAD	N/A	Office #114	2
47	1	X37 Heater	UHAAO31ATAD	N/A	Office #122	2
48	1	X38 Heater	UHAAO31ATAD	N/A	Office #123	2
49	1	X39 Heater	UHAAO31ATAD	N/A	Office #141	2
50	1	X40 Heater	UHAAO31ATAD	N/A	Office #144	2
51	1	X41 Heater	UHAAO31ATAD	N/A	Office #145	2
FIRE STATION #1 500 S. GLEBE ROAD						
NO.	QTY	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	AC-1	VR5-12	R15-80409	Storage Room	4
2	1	EF-1	G-150-BX-OD	98I09779	Roof	3
3	1	EF-3	4HZ29	N/A	Roof	3
4	1	EF-4	G-120-AX-OD	98J01478	Roof	3
5	1	EF-5	DB1210	N/A	Roof	3
6	1	EF-6	D1210	N/A	Roof	3
7	1	EF-7	RED08	N/A	Roof	3
8	1	EF-8	DB1809	N/A	Roof	3
9	1	BH-1	FTH/FUTG0N	30003544	Bay/Winter Only	1
10	1	BH-2	FTH/FUTG0N	30003545	Bay/Winter Only	1
11	1	BH-3	FTH/FUTG0N	30003546	Bay/Winter Only	1
12	1	BH-4	FTH/FUTG0N	30003543	Bay/Winter Only	1

FIRE STATION #5 1750 S Hayes Street						
		EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
Roof Top Units (Carrier)		RTU-1	48HGD016CC-5H5F	5004200064	Roof	4
		RTU-2	59016	2005-A MGD14808	Roof	4
		RTU-3	48HJDOO5G0551	4704G40376	Roof	4
		RTU-4	HFP225TMRHN4002	1015104-3217	Roof	4
Electric Fans		Unit	M/N	S/N	Location	
		EF-3	Modine/13E800AMPC	38100917090613-0106	Sprinkler Room	3
		EF-4	FSBT6D	40955-Z	Roof	3
		EF-5	100 CPS 100 CPS	14357955500 20002901	Roof	3
		EF-6	60 CPF CP6D17	143579555007 004201	Roof	3
		EF-8	100 CPF 100 CPFB	143579555002 0005401	Roof	3
		EF-10	100 CPF CP10D08	1435795550-02	Roof	3
		EF-11	90CPF CP9D11	14357955500- 20001809	Roof	3
		EF-12	180 ACE 180C7B	1435795550-01	Roof	3
		EF-13	180 ACE 180C7B	1435795550-01	Roof	3
Unit Heaters		Unit	M/N	S/N	Location	
		UH-1	CO306	38212105-6343		1
		UH-2	CW98			1
		UH #1/X-17	MUH0581		Bay	1
Boilers		Unit	M/N	S/N	Location	
		Boiler #1	GT215A	124	Mech. Room	1
Pumps		Boiler #2	GT215A	125	Mech. Room	1
		P-1	PL-80B	1BL013	Mech. Room	4
		P-2	BGC48517D67		Mech. Room	4
		P-3	GTV-TT		Mech. Room	4
		P-4	GTV-TT		Mech. Room	4
Air Handler Units (Carrier)		Unit	M/N	S/N	Location	
		AHU-1	FA4BNF024	4304A81896	Second Floor Hallway	4
		AHU-2	FA4BNF024	4304A81857	Second Floor Hallway	4
		AHU-3	FA4BNF036	4304A75166	Second Floor Hallway	4
Condenser Units		AHU-4	FA4BNF036	4304A75170	Second Floor Hallway	4
		AHU-5	FA4BNF024	4304A81890	Second Floor Hallway	4
		AHU-6	FA4BNF024	4304A81897	Second Floor Hallway	4
		Unit	M/N	S/N	Location	
		CU-1	38CK024340	1304E42936	Roof	4
		CU-2	38CK024340	1304E42930	Roof	4
		CU-3	38CK5036300	4404E40397	Roof	4
		CU-4	38CK5036300	4404E40394	Roof	4
		CU-5	38CK024340	1304E42940	Roof	4
		CU-6	38CK024340	1304E42938	Roof	4
Electric Unit Heater		Unit	M/N	S/N	Location	
		EUH #1	WH4404		Sprinkler Room	1
Radiant Heater		EUH #3	WH4404			1
		Unit	M/N	S/N	Location	
		RH #1/X-14	ET(US) 150N5	272335	Bay	1
		RH #2/X-15	ET(US) 160N5	272333	Bay	1
Trane Units		RH #3/X-16	ET(US) 160N5	272336	Bay	1
		AHU/M-1	122243TF2V	TAM8A0C48V41CBA	Basement	4
		CU-1	12402KY41F	4TWZ0048B1000AA	Outside	4
		BH #1	2-80-1175	MUH-05-2 mg	Bay	1
		BH #2	11-81-1429	MUH-05-2 mg	Bay	1
Trane Units		BH #3	N/A	2YU62	Bay	1

FIRE STATION #9 1900 WALTER REED DRIVE						
		EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
Exhaust Fan		Carnes	M/N VEBK08L1A1UA20SPC	S/N 497804001	Roof	3
		Carnes	VEBK08L1A1UA20SPC	S/N 497804003		3
		Carnes	VEBK08L1A1UA20SPC	S/N 497804002		3
		Kitchen Exhaust	VUBK08L12R1B1UA20S_CX	S/N 497804-004		3
		Exhaust Fan	N/A	N/A		
Condensing Units		Unit	M/N	S/N	Location	
		Trane	4TTZ0060A1000	13171NUS1F	Outdoor Inspection Months: 3, 5, 7, 9	4
		Trane	4TTZ0060A1000	13164J1G1F	Outdoor Inspection Months: 3, 5, 7, 9	4
		Trane	4TTZ0060A1000	1313157C1F	Outdoor Inspection Months: 3, 5, 7, 9	4
		Trane	4TTZ0060A1000	12252PCJ1F	Outdoor Inspection Months: 3, 5, 7, 9	4
		Trane	4TTZ0048B1000	1317355J1F	Outdoor Inspection Months: 3, 5, 7, 9	4
Air Handlers		Unit	M/N	S/N	Location	
		Trane	4TXCC060BC3	131921PX5G		12
		Trane	4TXCC060BC3	131921HD5G		12
		Trane	4TXCC060BC3H	131915W15G		12
		Trane	4TXCC060BC3H	131921GT5G		12
Heat Unit		Reznor	RPB300-8-2	BMG94X3N31786X	Gas-fired, serves Engine Bay	1
		5 dehumidifiers			Mechanical room Inspection Months: 9, 11, 1, 3	4
FIRE TRAINING CENTER 2800 S. TAYLOR STREET						
	UNIT	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
Heat Pump	HP1	Trane	4TWZ0024A1000	92533GH1F	Outdoor Inspection Months: 3, 5, 7, 9	4
	HP2	Trane	4TWZ0024A1000	10095WG11F	Outdoor Inspection Months: 3, 5, 7, 9	4
	HP3	Trane	4TWZ0024A1000	92533H71F	Outdoor Inspection Months: 3, 5, 7, 9	4
	HP4	Trane	4TWZ0024A1000	1026525L1F	Outdoor Inspection Months: 3, 5, 7, 9	4
	HP5	Trane	4TWZ0024A1000	10492LKY1F	Outdoor Inspection Months: 3, 5, 7, 9	4
	HP6	Trane	4TWZ0024A1000	92544801F	Outdoor Inspection Months: 3, 5, 7, 9	4
	HP7	Trane	4TWZ0024A1000	10095W4J1F	Outdoor Inspection Months: 3, 5, 7, 9	4
	HP8	Trane	4TWZ0036A1000	92544801F	Outdoor Inspection Months: 3, 5, 7, 9	4
	HP9	M. Slim	PUZ-A18NHA4	0ZU00571A	Outdoor Inspection Months: 3, 5, 7, 9	4
	HP10	Trane	4TWA3036A3000	11143MHD2F	Outdoor Inspection Months: 3, 5, 7, 9	4
Air Handlers	Unit	Type	M/N	S/N	Location	
	AH 1	Trane	4TEE3C03A1000	10286M931V		12
	AH 2	Trane	4TEE3C03A1000	10286M921V		12
	AH 3	Trane	4TEE3C03A1000	10274KW61V		12
	AH 4	Trane	4TEE3C03A1000	10253ST11V		12
	AH 5	Trane	4TEE3C03A1000	10253STS1V		12
	AH 6	Trane	4TEE3C03A1000	10253STN1V		12
	AH 7	Trane	4TEE3C03A1000	104220N71V		12
	AH 8	Trane	4TEE3C03A1000	10253STM1V		12
	AH 9	M. Slim	4TEE3C03A1000	02A01077A		12
Heat Recovery Unit	Unit	Type	M/N	S/N	Location	
	1		79MS1612	4478		4
Unit Heater	Unit	Type	M/N	S/N	Location	
	1	Reznor	F25	AQE31KSN21090		1
		Dayton	3UF62D	4104-2491-003		1
GLEN CARLYN LIBRARY 300 S Kensington St						
	UNIT	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION	INSPECTION #S
Heat Pump		Trane	4TWX8036C	15185PF42F	Out door	4
		Trane	4TWX8060A	15174NMM2F	Out door	4
		Trane	4TWX8060A	1513472A2F	Out door	4
Air Handlers		Unit	M/N	S/N	Location	
		Trane	TAM7AOC36	143016JAV	Attic	4
		Trane	TAM7BOC60H51SC	14403NARAV	Attic	4
		Trane	TAM7BOC60H51SC		Attic	4

GUNSTON BUBBLE 2700 S. LANG ST.						
UNIT	MODEL NO.	SERIAL NO.	LOCATION	INSPECTION #/S		
UH (used to pressurize bldg)	UH 1	HBG800AMPLN40	30100917090613-	Out door	12	
	AHU1	1902	standby	12		
	AHU2	Modine/13E800AMPC	30100917090613- B106	primary	12	
IMPOUND LOT 4250 29TH STREET						
UNIT	MODEL NO.	SERIAL NO.	LOCATION	INSPECTION #/S		
Air Handler Unit (All Trane)	M-1/AHU	4TEC3F36B1000AA	73318511V	Bay 1	4	
	M-2/AHU	4TEC3F36B1000AA	7332AJJ1V	Bay 2	4	
	M-3/AHU	4TEC3F24B1000AA	73315UX1V	Bay 3	4	
	M-4/AHU	4TEC3F24B1000AA	7331N4R2V	Bay 4	4	
	M-5/AHU	4TEC3F24B1000AA	73315UX1V	Bay 5	4	
Condenser	M-6/Condenser	4TTB3036A1000AA	6342P1G1F	Bay 1	4	
	M-7/Condenser	4TTB3036A1000AA	7171P1263F	Bay 2	4	
	M-8/Condenser	4TTB3024A1000AA	7025TF01F	Bay 3	4	
	M-9/Condenser	4TTB3U24A1000AA	70250GW1F	Bay 4	4	
	M-10/Condenser	4TTB3024A1000AA	70250HX1F	Bay 5	4	
	M-11	LP123HD3A	001KAPW02328	Office	4	
Heater	J-1/Heater	QVF-60S	H04312541000018	Bay 1	1	
	J-2/Heater	QVF-60S	H04312541000012	Bay 2	1	
	J-3/Heater	SSUB-P10601AN2AA110	H04312541000011	Bay 3	1	
	J-4/Heater	QVF-60S	H04312541000009	Bay 4	1	
	J-5/Heater		H04312541000013	Bay 5	1	
Exhaust Fans	X-1	Greenback	*	Bay 1	3	
	X-2	Greenback	*	Bay 2	3	
	X-3	Greenback	*	Bay 3	3	
	X-4	Greenback	*	Bay 4	3	
	X-5	Greenback	*	Bay 5	3	
	X-6/Lab Hood Exhaust	Greenback	*	Bay 1	3	
	X-7	Broan	*	Office Bathroom	3	
LONG BRANCH NATURE CENTER 625 S. CARLIN SPRING						
EQUIPMENT	MODEL NO.	SERIAL NO.	LOCATION	INSPECTION #/S		
Split System Heat Pumps	ACU-1	FE4ANB006	5111A84893	Lg. mtg. rm.	4	
	ACU-2	FE4ANB003	3411A84301	Attic	4	
	ACU-3	ASU24RLF	KTA006900	Attic	4	
	ACCU-1	25HNB960A300	0112E07369	Rear of bldg.	4	
	ACCU-2	25HNB936A300	3711E13979	Rear of bldg.	4	
	ACCU-3	AOU24RLXFW	KTN005566	Front of bldg.	4	
Exhaust Fans	Unit	Model #	Serial#	Location		
	EF-1	Broan/B490	Typical	Rear Bldg.	3	
	EF-2	Broan/B490	Typical	Rear Bldg.	3	
	EF-3	Broan/8170	Typical	Kitchen	3	
	EF-4	Broan/B490	Typical	Far side of Bldg.	3	
	EF-5	Broan/B490	Typical	Women's rm.	3	
	EF-6	Broan/B490	Typical	Men's rm.	3	
Unit Heaters	Unit	Model #	Serial#	Location		
	UH-1	Electromode/WJA-12	Typical	Women's rm.	1	
	UH-2	Electromode/WJA-12	Typical	Men's rm.	1	
MOTOROLA BUILDING 2701 S. NELSON STREET						
EQUIPMENT	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #/S		
Split System Carrier	Split System	CK3BXA042021AAAA	0499X29781		4	
Heater Reznor	Unit	M/N	S/N	Location		
	H1	Reznor	*	Space heater for Warehouse	1	
	H2	Reznor	*	Space heater for Warehouse	1	
Heat Pumps (3 ton)	Unit	M/N	S/N	Location		
	HP1	NHP042AKA1	L022449932		4	
	HP2	AMSTAND/4A6C 3048AQ38000BA	9402DF2F	police/ roof	4	
	Hp3	Carrier	*	shop/ roof	4	
TRAFFIC ENGINEERING WAREHOUSE 4280 S. 29TH STREET						
EQUIPMENT	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #/S		
Fan	H-1/AC	HE019-1HZC	BH072941D	Second Floor	1	
Radiant heater	J-1/Heater	CHC-015A	7GG01798	First Floor	1	
	J-2/Heater	CHC-015A	7GG01798	First Floor	1	
	Water Heater	DEL30110	1149M002889	ENG. WAREHOUSE 2	1	
	EUH	CH2724-3B		ENG. WAREHOUSE 2	1	
	HEAT PUMP	WMR10BC0H21503G	17110538	OFFICE	4	

RESIDENTIAL PROGRAM CENTER (RPC) 1554 COLUMBIA PIKE						
NO.	QTY.	EQUIPMENT	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	AHU - L1	BCHD012A1L0A	T18L43448		4
2	1	AHU - L2	BCHD012A1L0A	T18L43449		4
3	1	AHU - L3	BCHD012A1L0A	T18L43456		4
4	1	AHU - 5R	BCHD024A1L0A	T18L43451		4
5	1	AHU - 6R	BCHD024A1L0A	T18L43452		4
6	1	AHU - 7R	BCHD024A1L0A	T18L43458		4
7	1	AHU - 8L	BCHD054G1L0A	T18L43453		4
8	1	AHU - 9L	BCHD024A1L0A	T18L43457		4
9	1	AHU - 11L	BCHD036A1L0A	T18L43455		4
10	1	AHU - 10L	BCHD012A1L0A	T18L43454		4
11	1	AHU - 11L	TBD			2
12	1	FCU	138	T18L43475	Inspections Plus Filter Changes	4
13	1	FCU	139	T18L43466	Inspections Plus Filter Changes	4
14	1	FCU	140	T18L43464	Inspections Plus Filter Changes	4
15	1	FCU	BEDROOM RIGHT UNIT 101	T18L43463	Inspections Plus Filter Changes	4
16	1	FCU	BEDROOM LEFT UNIT 101	T18L43501	Inspections Plus Filter Changes	4
17	1	FCU	HALL UNIT 104	T18L43489	Inspections Plus Filter Changes	4
18	1	FCU	BEDROOM 103	T18L43508	Inspections Plus Filter Changes	4
19	1	FCU	BEDROOM 105	T18L43486	Inspections Plus Filter Changes	4
20	1	FCU	LAUNDRY ROOM 109	T18L43494	Inspections Plus Filter Changes	4
21	1	FCU	ROOM 110	T18L43492	Inspections Plus Filter Changes	4
22	1	FCU	ROOM 111	T18L43499	Inspections Plus Filter Changes	4
23	1	FCU	ROOM 112	T18L43472	Inspections Plus Filter Changes	4
24	1	FCU	ROOM 116	T18L43507	Inspections Plus Filter Changes	4
25	1	FCU	ROOM 117	T18L43473	Inspections Plus Filter Changes	4
26	1	FCU	ROOM 118	T18L43500	Inspections Plus Filter Changes	4
27	1	FCU	HALLWAY OUTSIDE DINING RM 122	T18L13460	Inspections Plus Filter Changes	4
28	1	FCU	DINING ROOM 126	T18L43493	Inspections Plus Filter Changes	4
29	1	FCU	FRONT OFFICE 128	T18L43474	Inspections Plus Filter Changes	4
30	1	FCU	OFFICE 134	T18L43497	Inspections Plus Filter Changes	4
31	1	FCU	OFFICE 135	T18L43502	Inspections Plus Filter Changes	4
32	1	FCU	HEALTH ROOM 137	T18L43468	Inspections Plus Filter Changes	4
33	1	FCU	MAIN ENTRANCE VESTIBULE 142	T18L43459	Inspections Plus Filter Changes	4
34	1	FCU	LAUNDRY 153	T18L43495	Inspections Plus Filter Changes	4
35	1	FCU	OFFICE 154	T18L43483	Inspections Plus Filter Changes	4
36	1	FCU	OFFICE 157	T18L43480	Inspections Plus Filter Changes	4
37	1	FCU	OFFICE 158	T18L43477	Inspections Plus Filter Changes	4
38	1	FCU	OFFICE 160	T18L43505	Inspections Plus Filter Changes	4
39	1	FCU	CONFERENCE ROOM 161	T18L43491	Inspections Plus Filter Changes	4

Page 3

40	1	FCU	BEDROOM 204	T18L43461	Inspections Plus Filter Changes	4
41	1	FCU	BEDROOM 205	T18L43465	Inspections Plus Filter Changes	4
42	1	FCU	GROUP ROOM 206	T18L43484	Inspections Plus Filter Changes	4
43	1	FCU	GROUP ROOM 209-A	T18L43488	Inspections Plus Filter Changes	4
44	1	FCU	GROUP ROOM 209-B	T18L43485	Inspections Plus Filter Changes	4
45	1	FCU	BEDROOM 214	T18L43503	Inspections Plus Filter Changes	4
46	1	FCU	BEDROOM 216	T18L43478	Inspections Plus Filter Changes	4
47	1	FCU	BEDROOM 220	T18L43509	Inspections Plus Filter Changes	4
48	1	FCU	BEDROOM 222	T18L43479	Inspections Plus Filter Changes	4
49	1	FCU	BEDROOM 223-A	T18L43471	Inspections Plus Filter Changes	4
50	1	FCU	BEDROOM 223-B	T18L43476	Inspections Plus Filter Changes	4
51	1	FCU	BEDROOM 225	T18L43482	Inspections Plus Filter Changes	4
52	1	FCU	BEDROOM 227	T18L43506	Inspections Plus Filter Changes	4
53	1	FCU	BEDROOM 228	T18L43469	Inspections Plus Filter Changes	4
54	1	FCU	BEDROOM 231	T18L43470	Inspections Plus Filter Changes	4
55	1	FCU	BEDROOM 232	T18L43487	Inspections Plus Filter Changes	4
56	1	FCU	BEDROOM 234-A	T18L43504	Inspections Plus Filter Changes	4
57	1	FCU	BEDROOM 234-B	T18L43462	Inspections Plus Filter Changes	4
58	1	FCU	BEDROOM 236	T18L43490	Inspections Plus Filter Changes	4
59	1	FCU	BEDROOM 237-A	T18L43481	Inspections Plus Filter Changes	4
60	1	FCU	BEDROOM 237-B	T18L43467	Inspections Plus Filter Changes	4
61	1	Unit Heaters	TBD			1
62	1	Unit Heaters	TBD			1
63	1	Unit Heaters	TBD			1
64	1	Split System	TBD			4
65	1	Exhaust Fans	TBD			3
66	1	Exhaust Fans	TBD			3
67	1	Exhaust Fans	TBD			3
68	1	Exhaust Fans	TBD			3
69	1	Exhaust Fans	TBD			3
70	1	Exhaust Fans	TBD			3
71	1	Exhaust Fans	TBD			3
72	1	Exhaust Fans	TBD			3
73	1	Exhaust Fans	TBD			3
74	1	Exhaust Fans	TBD			3
75	1	Pumps	TBD			4
76	1	Pumps	TBD			4
77	1	Pumps	TBD			4
78	1	Pumps	TBD			4
79	1	Electric Heaters	TBD			1
80	1	Electric Heaters	TBD			1
81	1	Electric Heaters	TBD			1
82	1	Electric Heaters	TBD			1
83	1	Electric Heaters	TBD			1
84	1	Chiller	CGAM - TBD		Summer	4
SHIRLINGTON STATION 2975 S. QUINCY ST.						
NO.	QTY.	UNIT	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Selft Contained Unit	VA8G3A	712073	Serves The Entire Building - Clean Condenser Two Times	12
2	1	EF-1	ILG/Exhaust Fan MN: SQBA 08	*	Restrooms	3

SHIRLINGTON LIBRARY/SIGNATURE THEATRE						
4200 CAMPBELL AVENUE						
NO.	QTY	EQUIPMENT TYPE	MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Air Handling Unit	Temtrol		AHU-1, 12,000 CFM, cooling and heating coil	4
2	1	Air Handling Unit	Temtrol		AHU-2, 6,000 CFM, cooling and heating coil	4
3	1	Air Handling Unit	Temtrol		AHU-3, 21,000 CFM, cooling and heating coil	4
4	1	Air Handling Unit	Temtrol		AHU-4, 12,000 CFM, cooling and heating coil	4
5	1	Air Handling Unit	Temtrol		AHU-5, 15,500 CFM, cooling and heating coil	4
6	1	Air Handling Unit	Temtrol		AHU-6, 2,500 CFM, cooling and heating coil	4
7	1	Cooling Tower	Baltimore Aircoil VTL227/OX	U052215801		4
8	2	Pump	B&G M/N 3 G, Series 1510		Chilled water, end suction, 20 Hp	4
9	2	Pump	B&G M/N 2 BC, Series 1510		Heating water, end suction, 7.5 Hp	4
10	2	Pump	B&G M/N 5 E, Series 1510		Condenser water, end suction, 10 Hp	4
11	6	Pump	B&G		In-line circulators, serves AHUs	4
14	1	Relief Fan	ACME M/N DCH42L		RF-1, serves AHU-1, 2 Hp, 11,500 CFM	4
15	1	Relief Fan	ACME M/N K24J		RF-2, serves AHU-2, 1 Hp, 5,600 CFM	4
16	1	Relief Fan	Temtrol/mfg date 5/13/2005 WF	U101659-003-00	RF-3, serves AHU-3, 15 Hp, 12,000 CFM	4
17	1	Relief Fan	Trane M/N QFCA30		RF-4, serves AHU-4, 5 Hp, 12,000 CFM	4
18	1	Relief Fan	Trane M/N QFCA36		RF-5, serves AHU-5, 7.5 Hp, 13,500 CFM	4
19	7	Exhaust Fan	ACME		EF-1, EF-2, EF-5, EF-6, EF-7, EF-8, EF-9	3
20	2	Exhaust Fan	ACME M/N ECH72P		EF-3, EF-4, smoke purge, 40,800 CFM, 7.5 Hp	3
21	2	Expansion Tank	B&G		ET-1, ET-2	1
22	3	Unit Heater	Qmark		Electric heater	1
23	1	Split System	Mistubishi		N/A	4
24	1	Split System	M/N Mr. Slim		N/A	4
25	1	Hot Water Heater				1
SOLID WASTE/TRAFFIC DIVISION BUILDING						
4300 S. 29TH STREET						
Heater		EQUIPMENT	MODEL NO.	SERIAL NO.	LOCATION	INSPECTION #S
		H-7	285458700	AUBA425294	Garage. McQuay	1
		H-8	HE0623H	BHD72942	Garage. AP Energy Systems	1
		Unit	M/N	S/N	Location	
Exhaust Fan		Ex. Fan #1	*	*	Roof	3
		Ex. Fan #2	*	*	Roof	3
		Ex. Fan #3	*	*	Roof	3
		Unit	M/N	S/N	Location	
Boiler		Boiler	211A-04-W/S	426223-200303	Mechanical Room. Peerless	1
		HX	UX-216-HJ-37	P14973 H	Mechanical Room. Superchanger	1
		Unit	M/N	S/N	Location	
Cooling Tower		Cooling Tower	VTO-041-J	UO40176901	Outside. BAC	4
		Unit	M/N	S/N	Location	
Heat Pump		HP-1	CW09R011CMNBSSD	09060164D	Workshop	4
		Unit	M/N	S/N	Location	
		Computer Lab AC	CW09R011CMNBSSD	90601641	Workshop	4
		AC-1	GEHE06031A0100BRO	W09H08358	Operations Room. Trane	4
		AC-2	WCH52060	AUBA425293	Workshop	4
		AC-3	50H0A019	5294V25083	Workshop	4
		AC-4	HG060	70303088	Workshop	4
		AC-5	WCH51090	AUBA378921	Workshop	4
		AC-6	WCH51036	AWBA425220	Workshop	4
		AC-9	CCH/HWH030	580022806	Room 104	4
		AC-10	HSD24GS	H10404127	Main Office/Hallway	4
		AC-11	H5030G521G8C5B	H17325764	Main Office/Hallway	4

		Unit	M/N	S/N	Location	
Fan Coil		Fan Coil #5	McQuay/TSF-061C-A	HH02087-02	Men's Bathroom	2
		Fan Coil #6	TSF-061C-A	HH02770-02	Men's Bathroom	2
		Fan Coil	WWMF2019E200U12AA	AUBU071200976	Room 115	2
		Fan Coil	WWMF2019E200U12AA	AUBU071200974	Room 107	2
		Fan Coil	CS007GROBASS0A	94K025722	Room 112	2
		Fan Coil/J-10	*	*	Boiler Room	2
Unit heater		Unit	M/N	S/N	Location	
		J-3/Heater	5VX678	TYPICAL	Garage	1
		J-4/Heater	5VX678	TYPICAL	Garage	1
Boiler		Unit	M/N	S/N	Location	
		Boiler Pump #1	5K43MG5813H	N/A	Mechanical Room	1
		Boiler Pump #2	5K43MG5813H	N/A	Mechanical Room	1
Pumps		Unit	M/N	S/N	Location	
		Cond. Pump/P5	M3218T	N/A	Mechanical Room. Baldor	4
		Stand By/P4	M3218T	N/A	Mechanical Room. Baldor	4
		P3	Baldor	M3218T	Mechanical Room. Baldor	4
1	1	Boiler	Peerless 211A-04-W/S	S/N 426223-200303		1
2	1	Cooling Tower	Baltimore AirCoil M/N VTO-041-J S/N 4040176901		3 Hp	4
3	2	Pump	Taco M/N 1616C		1 Hp, in-line	4
4	3	Pump	Taco M/N SB2508-7		0.95 Hp, base mounted	6
5	4	Exhaust Fan	Penn Domex			3
6	9	Exhaust Fan	Carnes Domex SuperCharger			3
7	1	Heat Exchanger	M/N 4X-216-HJ-37 S/N P14973H			1
8	2	Heat Pump	FHP M/N HE 062-3HZ			4
9	1	Heat Pump	McQuay M/N CCH/HWH030 CNFS			4
10	1	Heat Pump	Carrier M/N 50HQ192EC301			4
11	1	Heat Pump	Carrier M/N 50H0D060SMC501			4
12	4	Heat Pump	Friedrich M/N H-62-32		5 Hp	4
13	1	Heat Pump	Friedrich M/N 800-07G		1/2 Hp	4
14	5	Heat Pump	McQuay M/N WMH019CMGR			4
15	1	Heat Pump	Friedrich M/N 800-12G			4
16	1	Heat Pump	McQuay M/N WE750C50			4
17	1	Heat Pump	McQuay M/N TSF061C		Heating only	4
18	1	Heat Pump	Climate Master M/N CS007GR0BASSD5A S/N 94K025722			4
19	1	Heat Pump	McQuay M/N TSB031C		Heating only	4
20	1	Heat Pump	McQuay M/N TSF081C		Heating only	4
21	5	Heat Pump	McQuay M/N TSC151C		Heating only	4
22	2	Heat Pump	McQuay M/N WWMF2019EZ00U12AA14AIA2			4
23	1	Heat Pump	Friedrich M/N 800-09G-D2L-013 S/N 900431			4
24	6	Heat Pump	McQuay M/N WCMS1036FZ00Z00AC12ZZAI			4
25	1	Heat Pump	Climate Master M/N HS060HSZZLZGCSA S/N H10303088			4
26	2	Heat Pump	Climate Master M/N HS024GSZSLSGCSB S/N H10404127			4
VEHICLE WASH 4260 S. 28TH STREET						
NO	QTY	EQUIPMENT	MODEL NO.	SERIAL NO.	LOCATION	INSPECTION #S
1	1	Heat Pump	A42HC09K	XXEXA60	Break room	4

WALTER REED COMMUNITY CENTER 2909 S. 16TH STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL/SERIAL NO.		LOCATION/REMARKS	INSPECTION #S
1	4	VAV Box	Titus			
			M/N DESV			2
2	11	Fan Powered VAV	Titus		Parallel	2
3	7	Fan Powered VAV	Titus			
			M/N DTQS			2
4	1	Fan Coil Unit	McQuay		FCU-1	
			M/N TSC			2
5	4	Unit Heater	McQuay		340 CFM, heating coil	
			M/N UH			1
6	2	Boiler	Thermal Solutions		Gas-fired, 880 MBH output	
			M/N EVH-1000			1
7	2	Pump	Taco		Heating water pumps	4
8	2	Pump	Taco		Chilled water pumps	4
9	3	Roof Top Unit	Aaon		Contains heat wheel, 20-ton	12
10	2	Roof Top Unit	Aaon		Contains heat wheel, 26-ton	12
11	1	Chiller	McQuay M/N AGS		Air-cooled, screw compressors	
13	1	Split System	Mitsubishi/PKA-A12HA7	63A03334B	Communications room	4
14	1	Kitchen Exhaust	Greenheck		KEF-1, 850 CFM, upblast	
			M/N CUE			6
15	6	Exhaust Fan	Greenheck		EF-1 through EF-6	3
16	4	Unit Heaters	TPI	Typical	Vestibule and mechanical rooms	1

WATER/SEWER/MAINTENANCE AND WAREHOUSE 4202 S. 28TH STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL	SN	LOCATION/REMARKS	INSPECTION #S
	1	CONDENSER UNIT	4TTA3060D	12194JGB4F	OUTSIDE	4
	1	CONDENSER UNIT	4TTA3060D	12134TDN4F	OUTSIDE	4
	1	HEAT PUMP	MUZGEIZNA			4
	1	SPLIT SYSTEM HP	MSZGERNA			4
	1	AHU	4TXCDD061	11383PHJ5G	GENERATOR ROOM	4
	1	AHU	4TXCDD061	11464XMSJG	GENERATOR ROOM	4
	1	WATER HEATER	GS650YBRT	0912A0165126	GENERATOR ROOM	1
	1	AHU	H2B1216	200404-CBCB01751	2ND FLOOR	4
	1	GAS FURNACE	QVD-1256	E0447338001001	2ND FLOOR	1
	1	Exhaust Fan	120CPF	1435782960	ROOR	3

WATER/SEWER/STREETS ADMINISTRATION 4200 S. 28TH STREET						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL		LOCATION/REMARKS	INSPECTION #S
1	1	Split System	Trane Chiller Air Cool Chiller/RAUJC40EEB03ABDF00000	C11G04018	The chiller provides the cooling to the AHU-1 which serves all the VAV's for the entire building	4
			TRANE AHU-1/CSAA021UAC00	K11G77542		
2	1	Split System	SAMSUNG/ INDOOR UNIT MN: AQV09NSD	Production date 2011.03	Serves server closet/LAN ROOM on top floor	4
			SAMSUNG/ OUTDOOR UNIT/MN: AQV09NSDX	Production date 2011.03		
3	2	Bard Self Contained Unit	TBD	TBD	Trailer	4

WETA BUILDING 3700 S. FOUR MILE RUN						
NO	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL		LOCATION REMARKS	INSPECTION #S
1	1	Heat Pump	Trane M/N TWE030C140B0	S/N Z133TEY1V	2 ton	4
2	3	Power Roof Ventilator	Greenheck		restroom	3
			M/N G-131-BX-QD			
			M/N G-080-DGEX-QD			
			M/N G-141-BX-QD			
3	2	Boiler	Burnham		Three pass	1
			M/N 4FW-127-40-G-GP			

ARLINGTON RAPID TRANSPORTATION (ART HOUSE III BUILDING) 2900 S. EADS ST.						
NO.	QTY	EQUIPMENT TYPE	MODEL/SERIAL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	RTU-1	RN-008-8-0-EA09-329 (AAON)	201209-ANGH	Building-Roof(8 RTUs but we only service 2	4
2	1	RTU-2	RN-011-8-0-EB0A-3F9 (AAON)	201209-ANGZ24H	Building-Roof(8 RTUs but we only service 2	4
3	1	EF-1	BROAN - N/A	N/A	Building	3
4	1	EF-2	BROAN - N/A	N/A	Building	3
5	1	EF-3	BROAN - N/A	N/A	Building	3
6		UH-1	TP1 - N/A	N/A	Main Entrance	1
	10	VAV Boxes	Titus	896392-	101 area & Dispatch	2
3RD ST. GROUP HOME 5409 3RD ST.						
NO.	QTY	EQUIPMENT TYPE	MODEL	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Air Handling Unit	Trane	TUHCM100	TBD	4
2	1	Condensing Unit	Trane	4TW20036	TBD	4
CULPEPPER 2217 N. CULPEPPER STREET						
NO.	QTY	EQUIPMENT TYPE	MODEL	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Furnace	Goodman		mechanical room	4
2	1	Condenser	Goodman		mechanical room	4
ARLINGTON MILLS 909 S. DINWIDDIE STREET						
NO.	QTY	EQUIPMENT TYPE	MODEL	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
		Heaters				
1	1	J-1	UHSB0841TAA	F12G3385B	RM G07 (G2 Level)	1
2	1	J-2	UHSB0841TAA	No Access	RM G07 (G2 Level)	1
3	1	J-3	UHSB0841TAA	F12G33590	RM G07 (G2 Level)	1
4	1	J-4	UHSB0841TAA	F12G33587	RM G03 (G2 Level)	1
5	1	J-5	UHSB0841TAA	F12G33589	RM G03 (G2 Level)	1
6	1	J-6	UHSB0841TAA	F12G33591	RM G06 (G2 Level)	1
7	1	J-7	MUH0571	N/A	Storage Room (G2 Level)	1
8	1	J-8	MUH0571	N/A	Storage Room (G2 Level)	1
9	1	J-9	MUH0571	N/A	Storage Room (G2 Level)	1
10	1	J-10	MUH0571	N/A	Storage Room (G2 Level)	1
11	1	J-11	MUH0571	N/A	Storage Room (G2 Level)	1
12	1	J-12	MUH0571	N/A	Storage Room (G2 Level)	1
13	1	J-13	MUH0571	N/A	Storage Room (G2 Level)	1
14	1	J-14	MUH0571	N/A	Storage Room (G2 Level)	1
		VAV Boxes				
15	15	PIU	Trane/VPW/VPWF	Typical	5th floor	2
16	1	VAV	Trane/VPW/VPWF	Typical	5th floor	2

17	12	PIU	Trane/VPW/VPWF	Typical	4th floor	2
18	2	VAV	Trane/VPW/VPWF	Typical	4th floor	2
19	14	PIU	Trane/VPW/VPWF	Typical	3rd floor	2
20	2	VAV	Trane/VPW/VPWF	Typical	3rd floor	2
21	10	PIU	Trane/VPW/VPWF	Typical	2nd floor	2
		Boilers				
22	1	B-1	PHW-2000	2951	Penthouse	1
23	1	B-2	PHW-2000	2785	Penthouse	1
		Water to Water Heat Exchanger				
24	1	HEX-1	NT100TBYF-150	ENA120/50218		1
		Exhaust Fans				
25	1	GEF-APL	No Access	No Access	PL Garage	4
26	1	GEF-B1PL	No Access	No Access	PL Garage	4
27	1	GEF-B2PL	No Access	No Access	PL Garage	4
28	1	GSF-C	54XLWHS	143SE22629-02	G2 Garage	4
29	1	GEF-C	No Access	No Access	G2 Garage	4
30	1	GEF-A	No Access	No Access	G2 Garage	4
31	1	GEF-B1	No Access	No Access	G2 Garage	4
32	1	GEF-B2	No Access	No Access	G2 Garage	4
33	1	GSF-D	300XLWS30XL	143SE22629-02	G2 Garage	4
34	1	GSF-B1	480XLWHS	143SE22629-02	G2 Garage	4
35	1	GSF-B2	480XLW	143SE22629-02	G2 Garage	4
36	1	GSF-A	240XLWS	143SE22629-S	G2 Garage	4
37	1	EF-1	200XLP 20XLP	143SE22629-02	Loading Dock Elec. Rm	3
38	1	EF-2	120SW 12S15D	143SE22629-02	Loading Dock Elec. Rm	3
39	1	EF-3	210S0N	143SE22629-01	Loading Dock	3
40	1	EF-4	120SW 12S15D	143SE22629-01	Rm G13 (G2 Garage)	3
41	1	EF-5	300CPF-3000CPFB	143SE22629-02	Roof	3
42	1	EF-6	No Access	No Access	Rm 144 (kitchen)	3
43	1	EF-7	No Access	No Access	Rm 124	3
44	1	EF-8	No Access	No Access	Rm 208	3
45	1	EF-9	No Access	No Access	Rm 303	3
46	1	EF-10	No Access	No Access	Rm 408	3
47	1	EF-11	No Access	No Access	Rm 509	3
48	1	EF-12	No Access	No Access	Rm G03	3
49	1	KEF-1	165VCRH	143SE22629-01	Roof	
50	1	Refrigerant Monitor	RMWERP411D0100	L12J03524		1
		Air Handler Units				
51	1	AHU-1	CSAA017UAC00	K12F59580	1st Floor	4
52	1	AHU-2	CSAA030UCA00	K12F59559	2nd Floor	4
	1	AHU-3	CSAA025UAC00	K12F59573	3rd Floor	4
	1	AHU-4	CSAA021UAC00	K12F59566	4th Floor	4
	1	AHU-5	CSAA025UAC00	K12G67116	Roof	4
	1	AHU-6	CSAA014UBC00	K12G67128	Gym Roof	4
	1	AHU-7	CSAA014UBC00	K12G67158	Gym Roof	4
	1	AHU-8	BVE40-2W-4W	W120958340	P.H.	4
	1	OAU-1	PCDH-65	09127771A	Roof	12
		Split Systems				
	1	CU-1	PUZA24NHA4	19U01913D	Garage 2	4
	1	CU-2	PUZA24NHA4	19U01876D	Garage 2	4
	1	CU-3	PUZA24NHA4	19U01930D	Garage 2	4
	1	CU-4	PUZA24NHA4	19U01929D	Garage 2	4
	1	CU-5	PUZA24NHA4	19U01907D	Garage 2	4
	1	CU-6	PUY-A18NHA4	24U05833C	Roof	4
	1	CU-7	PUY-A18NHA4	25U06108C	Roof	4
	1	CU-8	PUY-A18NHA4	25U06109C	Roof	4
	1	CU-9	PUY-A18NHA4	25U06175C	Roof	4
	1	CU-10	PUY-A18NHA4	25U05834C	Roof	4
	1	AHU-11	PKA-A24KA4	21M01003	G-22	4
	1	AHU-12	PKA-A24KA4	21M01007	G-04	4
	1	AHU-13	PKA-A24KA4	21M01006	G-05	4
	1	AHU-14	PLA-A24BA4	12A01858B	G2 Lobby	4
	1	AHU-15	PKA-A24KA4	23M01309	G-12	4
	1	AHU-16	PKA-A18HA4	26A06446C	RM 118	4
	1	AHU-17	PKA-A18HA4	26A06480C	RM 207	4
	1	AHU-18	PKA-A18HA4	26A06489C	RM 302	4
	1	AHU-19	PKA-A18HA4	26A06460C	RM 405	4
	1	AHU-20	PKA-A18HA4	26A06449C	RM 506	4

		Fan Coil Units				
	1	FCU-1	FCDB0601LA	T12G37334	Stair A. 1st Floor	2
	1	FCU-2	FCDB0601LA	T12G37335	Stair A. 3rd Floor	2
	1	FCU-3	FCDB0601LA	T12G37336	Stair A. 5th Floor	2
	1	FCU-4	FCDB0601LA	T12G37333	Stair C. 5th Floor	2
	1	FCU-5	FCDB0601LA	T12G37330	Stair C. 3rd Floor	2
	1	FCU-6	FCDB0601LA	T12G37332	Stair C. 1st Floor	2
	1	FCU-7	FCDB0601LA	T12G37331	Eng. Officer G-2	2
		Chillers				
	1	CH-1			Penthouse	
	1	CH-2			Penthouse	
		Cooling tower				
	1	CT-1	PT2-0709A-2J2	U123902202-01	Roof	4
		Cooling tower circulating pump				
	1	CTP-1	TC1-0100-SRV	59290-001	Roof	4
		Chiller water pumps				
	1	CHWP-1	01580T3E254TC	1016381876	Penthouse	4
	1	CHWP-2	01580T3E254TC	1016381878	Penthouse	4
	1	CHWP-3	01580T3E254TC	1016396471	Penthouse	4
		Condenser water pumps				
	1	CWP-1	010180T3E215TC	1016137333	Penthouse	4
	1	CWP-2	010180T3E215TC	1016279296	Penthouse	4
	1	CWP-3	010180T3E215TC	1016279293	Penthouse	4
		Boiler pumps				
	1	HWP-1	3X2X10 4030	711125	Penthouse	4
	1	HWP-2	3X2X10 4030	711126	Penthouse	4
	1	HWP-3	3X2X10 4030	711127	Penthouse	4
HEAD START BUILDNG 2920 S. GLEBE ROAD						
NO.	QTY	EQUIPMENT TYPE	MODEL	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
FC-1	1	JV-Mitsubishi Ductless Split (MXZ) Indoor Unit	SLZ-KA12NAR1.TH			2
HP-1	1	JV-Mitsubishi Ductless Split (MXZ) Indoor Unit	SUZ-KA12NAR1.TH			2
CNTRL	1	JV-Mitsubishi Ductless Split (MXZ) Indoor Unit	PAR-33MAA-J			2
UH-1-12	1	Indeeco Register Wall Heater	930U01500BW-D3T1		Garage Plenum	1
EF-1	1	Greenheck Series 21 Inclined Single Width	CSW-12-BI-21-10-015			3
EF-1	1	Greenheck Direct Drive Centrifugal Utility Fan	USDF-115-BI			3
VAV 1-1	1	Existing LCEF			Corridor 100	2
VAV 2-1	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 1409		Classroom 209	2
VAV 2-2	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 1409		Classroom 207	2
VAV 2-3	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 0809		Classroom 210	2
VAV 2-4	1	Trane Variable Air Volume Single Duct Terminal	VCCF08		Classroom 210	2
VAV 2-5	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 1409		Resource 212	2
VAV 2-6	1	Trane Variable Air Volume Single Duct Terminal	VCCF06		Library 203	2

VAV 2-7	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 0809		Classroom 218	2
VAV 2-8	1	Trane Variable Air Volume Single Duct Terminal	VCCF08		Classroom 218	2
VAV 2-9	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 1409		Classroom 221	2
VAV 2-10	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 1409		Classroom 223	2
VAV 2-11	1	Existing LCEF			Corridor 200	2
VAV 3-1	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 1409		Classroom 309	2
VAV 3-2	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 1409		Classroom 307	2
VAV 3-3	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 0809		Classroom 310	2
VAV 3-4	1	Trane Variable Air Volume Single Duct Terminal	VCCF08		Classroom 310	2
VAV 3-5	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 0809		Teach Lounge 312	2
VAV 3-6	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 0809		Classroom 318	2
VAV 3-7	1	Trane Variable Air Volume Single Duct Terminal	VCCF08		Classroom 318	2
VAV 3-8	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 1409		Classroom 321	2
VAV 3-9	1	Trane Low Height VAV Fan Powered Terminal Unit	LPEF 1409		Classroom 323	2
VAV 3-10	1	Trane Variable Air Volume Single Duct Terminal	VCCF08		Copy Room 303	2
VAV 3-11	1	Existing LCEF			Corridor 300	2
VAV 3-12	1	Existing LCEF			Pantry 315	2
RTU-1	1	Trane Rooftop Unit 25 Ton Existing	50A3C025-N521FF			4
RTU-2	1	Trane Rooftop Unit 25 Ton Existing	50A3C025-L-521FF			4

**ART LIGHT MAINTENANCE BUILDING
3201 S. EADS ST.**

NO.	QTY	EQUIPMENT TYPE	MODEL	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
	1	RTU-1	YHC036E4RXAIRDOB1A1	162610001L	ROOF	12
	1	MAU-1	A2-D 500-G15	23039010	ROOF	12
	1	MAU-2	A2-D 500-G15	23039010	ROOF	12
	2	B-1 & B-2	LOCHINVAR LWHN110		1ST FLOOR	1
	5	FIN TUBE RADIATORS	JVB-S		2ND FLOOR	1
	1	MINI-SPLIT AC-1/CU-1	4MYW6509A10N0BA	14040178X	1TCLOSET/2ND FLOOR	4
	4	Unit heater	UHSBA181TAA100A0000		1ST FLOOR	1
	1	CONVECTOR HEATER CV-1	FS-A-20		STAIRWELL 106	1
	1	CUH-1		T17F27819	ELEVATOR VESTIBULE	1
	4	EXHAUSF FAN	P12RA		110	3
	4	EXHAUSF FAN	A46-166DA-ALFCEC		109	3

**COURT POLICE FACILITY
1425 N. COURT HOUSE**

NO.	QTY	EQUIPMENT TYPE	MODEL	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Air Handler Unit #1	Buffalo Forge, 200-K	\$062740000001	1st floor mech room	6
2	1	Air Handler Unit #2	Buffalo Forge, 180-K	\$062740000002	2nd floor mech room	6
3	1	Air Handler Unit #3	Buffalo Forge, 300-K	\$062740000003	3rd floor mech room	6
4	1	Return Fan RF# 3	Buffalo Forge, 4389		3rd floor mech room	6
5	1	Air Handler Unit #4	Buffalo Forge, 105-K	\$062740000000	Ground floor mech room	6
6	1	Return Fan RF# 4	Buffalo Forge, 2248	\$088530000000	Ground floor mech room	6
7	1	Air Handler Unit #5	Buffalo Forge, K-200	\$062740000005	5th floor mech room	6
8	1	Air Handler Unit #6	Buffalo Forge, K-155	\$088530000002	6th floor mech room	6
9	1	Air Handler Unit #7	Buffalo Forge, K-155	\$06274-007	7th floor mech room	6
10	1	Air Handler Unit #8	BUFFALO FORGE, 1801K	\$06274-008	8th floor mech room	6
11	1	Air Handler Unit #9	BUFFALO FORGE, 180K	\$06274-09	9th floor mech room	6
12	1	Air Handler Unit #10	Buffalo Forge, 2401-K	\$062740000001	10th floor mech room	6
13	1	Return Fan RF# 10	Buffalo Forge, 3AB4	\$088550000000	10th floor mech room	6
14	1	Air Handler Unit #11	Buffalo Forge, 155-K	\$062740000001	12th floor mech room	6
15	1	Split Air Conditioning Unit	COND . 38BNB024311	2005V07016	5205 Computer room	6
16	1	CAHU 1 Liebert Unit	LIEBERT, BF071WDADE15965	NIIG740131 #2	7th floor Computer room	6
17	1	CAHU 2 Liebert Unit	LIEBERT, BF071WDADE15965	NIIG740131 #2	7th floor Computer room	6
18	1	CAHU 1	N/A		8th floor Sever RM 8205	6
19	1	CAHU 2	N/A		8th floor Sever RM 8205	6
20	1	Smoke Exhaust SEF #1	Buffalo Forge, 25A9 type	\$083530000000	Ground floor mech room	6
21	1	Staircase Pressure Fan SF1	300ABICW, 13thfl ceiling	4XD00104	Pent House	6
22	1	Staircase Pressure Fan SF2	300ABICW, 13thfl ceiling	4XD00104	Pent House	6
23	1	Staircase Pressure Fan SF3	300ABICW, 13thfl ceiling	4XD00104	Pent House	6
24	1	Staircase Pressure Fan SF4	300ABICW, 13thfl ceiling	4XD00104	Pent House	6
25	1	Exhaust Fan EF # 13	Stanley, DGE10		P1 Level Elev.	6
26	1	Garage Supply Fan GSF # 1	SQ-300-75	92B01305	Garage level	6

27	1	Garage Supply Fan GSF # 2	Snyder General, 270AFV	4YA00425	Garage level	6
28	1	Exhaust fan EF -P1-1	DOE10 1/29HP 4820T	FE 6-1 STANLEY FAN	Garage P2 Elev. Lobby	6
29	1	Exhaust fan EF-P2-2	CWD-080A	9YA0513001	Garage P2 Elev. Lobby	6
30	1	Exhaust fan EF-P2-3	DG E10 1/29 HP	4B207: CF12-1	Garage P2 Elev. Lobby	6
31	1	Exhaust fan EF-P2-4	N/A		Garage P2 Elev. Lobby	6
32	1	Exhaust fan EF-P2-5	DG E10 1/29HP 48207	EF7-1 STANLEY FAN	Garage P1 Elev. Lobby	6
33	1	Exhaust fan EF-1	Snyder General, BSI-120A	9YA0511301	1st floor Toilet exhaust	6
34	1	Exhaust fan EF-1-1	Stanley, DGE10		1st floor Comm. Exhaust	6
35	1	Exhaust fan EF-2	Snyder General, BSI-120A	9YA0511401	2nd floor Toilet exhaust	6
36	1	Exhaust fan EF-2-1	Dayton, 4C361F		2nd floor Comm. Exhaust	6
37	1	Exhaust fan EF-3-1	Snyder General, BSI-120A	9YA0511601	3rd floor Toilet exhaust	6
38	1	Exhaust fan EF-3-2	Snyder General, BSI-120A	9YA0512801	3rd floor Toilet exhaust	6
39	1	Exhaust fan EF-3-3	DG E10 1/29HP 48207	EF 5-1 STANLEY FAN	3rd floor Comm. Exhaust	6
40	1	Exhaust fan EF-4	Snyder General, BSI-140A	9YA0511801	4th floor Toilet exhaust	6
41	1	Exhaust fan EF-5	Snyder General, BSI-120A	9YA0511501	5th floor Toilet exhaust	6
42	1	Exhaust fan EF-5-1	Stanley, DGEIO		5th floor Comm. Exhaust	6
43	1	Exhaust fan EF-6	Snyder General, BSI120A	9YA0511901	6th floor Toilet exhaust	6
44	1	Exhaust fan EF-6-1	Stanley, DGEIO	48207	6th floor Comm. Exhaust	6
45	1	Exhaust fan EF-7	Greenheck, CSP-A1050-QD	10854388	7th floor Toilet exhaust	6
46	1	Exhaust fan EF-7-1	Stanley, DGE10		7th floor Comm. Exhaust	6
47	1	Exhaust fan EF-8	Snyder General, BSI-120A	9YA0512101	8th floor Toilet exhaust	6
48	1	Exhaust fan EF-8-1	Z-81		8th floor Toilet exhaust	6
49	1	Exhaust fan EF-8-2	Stanley, DGE10		8th floor Comm. Exhaust	6
50	1	Exhaust fan EF-9-1	Snyder General, BSI-120A	9YA0512201	9th floor Toilet & Locker exhaust	6
51	1	Exhaust fan EF-9-2	Quietaire, QIBKIO-MI	9605	9th floor-Dark Rm exhaust	6
52	1	Exhaust fan EF-9-3	Quietaire, QIBKIO-MI	9605	9th floor-Photo Pro Exhaust	6
53	1	Exhaust fan EF-9-4	Stanley, DGEIO		9th floor Comm Exhaust	6
54	1	Exhaust fan EF-9-5	Snyder General, 9AHCW	4YD00106	Level 13-Chem Pro (RM9400) Ex	6
55	1	Exhaust fan EF-10	Snyder General, BSI-120A	9YA0512301	10th floor Toilet exhaust	6
56	1	Exhaust fan EF-11-1	Snyder General, BSI-120A	9YA0512401	11th floor Toilet/ Holding exhaust	6
57	1	Exhaust fan EF-11-2	Snyder General, BSI-120A	9YA012501	11th floor Toilet/ Holding exhaust	6
58	1	Exhaust fan EF-12	Zephyr, Z-12HTDA		12th floor Toilet exhaust	6
59	1	Exhaust fan EF-12-1	Stanley Fans Inc., DGEIO		12th floor Comm Exhaust	6
60	1	Exhaust fan EF-14	DGE14 1/8 HP 48047		P-1 Fire Pump room exhaust	6
61	1	Exhaust fan EF-15	Stanley, LE425HP		P-2 Garage Exhaust-Garage	6
62	1	Exhaust fan EF-16	Stanley, LE425HP		P-2 Garage Exhaust-Garage	6
63	1	Exhaust fan EF-17	Stanley, LE425HP		RM	6
64	1	Exhaust fan EF-18	Stanley, LE425HP		P-2 Garage Exhaust	6
65	1	Exhaust fan EF-19	Soler & Palau, DB84	100066069	Atrium Roof Exhaust	4
66	1	Exhaust fan EF-20	N/A		Atrium Roof Exhaust	4
67	1	Exhaust fan EF-21	Snyder General, CWD-101A	QXA0513301	Pent House Elev Room Exhaust	6
68	1	Exhaust fan EF-22	9YA0513401 SNYDER	CWD-101A	Pent House Elev Room Exhaust	6
69	1	Exhaust fan EF-23	Snyder General, CWD-101A	9YA0513403	Pent House Elev Room Exhaust	6
70	1	Exhaust fan EF-24	9YA0513401 SNYDER	CWD-101A	P1 Level Elev. Room Exhaust	4
71	1	Exhaust fan EF-25	Dayton	N/A	Pent House Elev Room Exhaust	6
72	1	Exhaust fan EF-26	HIGH CEILING	0081BV11U273R12F	Pent House Mech Room Exhaust	6
73	1	Exhaust fan EF-27	US Electric, F106		Pent House Elev Room Exhaust	6
74	1	Exhaust fan EF-28	Magnatech, CAT4-E200	PART#355641	Pent House Elev Room Exhaust	6
75	1	Exhaust fan EF-29	Snyder General, CWD-101A	QX40513201	P1-Electrical room Exhaust	4
76	1	Exhaust fan EF-30	Quietaire, C1BK27		Ground Toilets/Locker exhaust	6
77	1	Exhaust fan EF-31	Snyder General, BSI-120A	9YA0512801	Riot Equip Work Rm Exhaust	6
78	1	Exhaust fan EF-32	Quietaire		Flare Exhaust	6
79	1	Exhaust fan EF-33	Quietaire, Q1BK08-L1	9605	Dry Rm Exhaust	6
80	1	Exhaust fan EF-G-1	Stanley, DGEIO		Ground Floor Comm Exhaust	4
81	1	Exhaust fan EF-34	9YAD511201	BSI-300A	13th floor Warehouse Exhaust	4
82	1	Exhaust fan EF-35	NO INFORMATION		13th floor Office Smoke Exhaust-IN CUSTODIAN OFFICE	4
83	1	Exhaust Fan for Generator Rm	210SQNB LOREN COOK	2130897-1 1/2HP	13th floor Generator Room	6
84	1	Fan Coil Unit FCU-1	TRANE, LC34A01906	S93A01906	Level 13th floor Office Space	2
85	1	Fan Coil Unit FCU-2	TRANE, RC34AL02U	S93A01909	Level 13th floor Shop Space	2
86	1	Cooling Tower CT-1	BAC 515E-1212-12MN-2	U188291803-01-01	Level 13th floor	4
87	1	Cooling Tower CT-2	BAC 515E-1212-12MN-2	U188291803-01-02	Level 13th floor	4
88	1	Boiler B-1	P.V.I., 125WBHE250A-TP		13th floor mech room	1
89	1	Boiler B-2	P.V.I., 125WBHE250A-TP		13th floor mech room	1
90	2	Chiller Water Pump CHW 1 & 2	B		13th floor mech room	4
91	2	Condenser Pumps CW 1 & 2	TACO 0075180T3E365T-W40		13th floor mech room	4
92	1	Water Treatment	Flow Tech HVAC ftc 100 ST 0257	FT43748	13th floor mech room	4
93	1	Refrigerant Monitor	Halo Guard 171-113-ALS (3)	6652-6652	13th floor mech room	4
94	1	Solid Filter	Lakos TBI-0232-ABV	1010521-001	13th floor mech room	4
95	2	Hot Water Pumps 5 & 6	Weinman, 3KH4A-200P46-V		13th floor mech room	4
96	1	Hot Water Circulating Pump #7	250TCV-20PN54C-V	210357 WEINMAN	13th floor mech room	4
97	2	Condenser Pump 8 & 9 for 7th/8th	312H14A-100P14 G-U	210360	13th floor mech room	4
98	1	Domestic HW Circulating Pump	Franklin Electric		13th floor mech room	4

99	1	Unit Heater Custodian Office area	5.0-RMT-12X10-2-2771	274695	13th floor mech room	1
100	1	Unit Heater by CT VFD Corridor	Trane, UHSA-042W-2C-AAC	D92L14490	13th floor mech room	1
101	1	Unit Heater Elevator Lobby	Trane, UHSA-042W-26-AAC	D92L14486	13th floor elevator lobby area	1
102	2	Unit Heaters in Mech Room	VHSA-042W-2C-AAC	D922L4488	13th floor main mech room	1
103	1	Unit Heater in Generator RM	VHSA-042W-2C-AAC	D922L4489	13th floor Generator Room	1
104	1	Duct Heater	Indeeco, 140-187567	C090563-1	13th floor mech room	1
105	1	Duct Heater above Radio room	US5A-042W-2C-AAC	D92L14493	13th floor electrical gear room	1
106	2	Split Air Conditioning Unit	Large Inverter Unit, LSN360HV2	30T219664, 302KAXV00098	Elev machine room 14th floor	4
107	1	Split A/C for Housekeeping Office	Carrier, 38CK060670	3605E26555	13th floor mech room	4
108	2	CHW Coil Unit for Elev. Machine RM	Carrier, 38YCB036600	0697E18604	13th floor mech room	4
109	1	Air Compressor AC-1 for Dry Pipe	EMGLO K2530S	805289190	P1-Fire Pump Room	1
110	1	HW Fan Coil Unit	Trane UHSA042WZDAAC	A95010823	Ground floor mech room	2
111	1	HW Fan Coil Unit	TRANE, UHSA042WZDAAC	A93K010824	3rd floor mech room	2
112	1	HW Fan Coil Unit	TRANE UHSA042WZDAAC	A93K010825	10th floor mech room	2
113	2	HW FCU in stairwell	NO INFORMATION		P1 Stairwell #3 & 4 each	2
114	1	HW Heating Unit	Trane, UHSA04WZDAAC	A93K010826	P1-Fire pump room	1
115	1	Heat Pump	Carrier, F134ANF042	2097A15929	13TH FL, 1/2HP, MECH RM. 1307	4
116	1	Exhaust Fan	Quietaire, C/BK21		G FLOOR, 3HP, EF-30, MECII ROOM G003	6
117	1	Exhaust Fan	DHE141	8HP 148047	SEWER PUMP RM, EF-14 C/P PUMP	6
118	1	Mitsubishi Split	TBD	TBD	Computer Room 7th Floor	6

**DENTENTION CENTER FACILITY
1435 N. COURT HOUSE**

NO.	QTY	EQUIPMENT TYPE	MODEL	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Air Handler Unit AHU #1	Trane CCDBA1P	K91K41318	Ground floor mech room	6
2	1	Return Fan #1	BSQ-240-50	92B01304	Ground floor mech room	6
3	1	Air Handler Unit AHU #2	Trane MCCA030GAB	K91K40507	Ground floor mech room	6
4	1	Air Handler Unit AHU #3	Trane MCCA025DAB	K91K40512	Ground floor mech room	6
5	1	Return Fan #3	Greenheck B5Q240-20	92801303	Ground floor mech room	6
6	1	Air Handler Unit AHU #4	Trane MCCA021MAB	K91K04513	2nd floor mech room	6
7	1	Return Fan #4			2nd floor mech room	6
8	1	Air Handler Unit AHU #5	Trane CCDB35HNIM	K91K41319	4th floor mech room	6
9	1	Return Fan #5	Greenheck		4th floor mech room	6
10	1	Air Handler Unit AHU #6	Trane CODB35LINM	K91K41320	6th floor mech room	6
11	1	Return Fan #6	Greenheck SWB-27-3		6th floor mech room	6
12	1	Air Handler Unit AHU #7	Trane CCDB35LNIM	K91K41321	8th floor mech room	6
13	1	Return Fan #7	Greenheck SWP-27-3U	92801344	8th floor mech room	6
14	1	Air Handler Unit AHU #8	Trane CC0835LNIM	K91K41322	10th floor mech room	6
15	1	Return Fan #8	Greenheck SWB-27-3C		10th floor mech room	6
16	1	Air Handler Unit AHU #9	Trane MCCA030 Gas	K91K40521	12th floor mech room	6
17	1	Return Fan #9	Greenheck S-JB-27-30	92B0134	12th floor mech room	6
18	1	Exhaust fan EF1	Marathon Elect, XF 256TT0570766		Parking Level	6
19	1	Exhaust fan EF2	Marathon Elect, XF 256TT0570766		Parking Level	6
20	1	Exhaust fan EF3	Marathon Elect, XF 256TT0570766		Parking Level	6
21	1	Exhaust fan EF4	Marathon Elect, XF 256TT0570766		Parking Level	6
22	1	Exhaust fan EF41	General Electric SK458G8004		Parking Level Mech room	6
23	1	Exhaust fan EF9	Greenheck SPFE-24-7	9280133	Ground level-Sally port	6
24	1	Exhaust fan EF10	Greenheck, BPSE-30-016-294	92B01134A	Ground floor Loading Dock	6
25	2	HW Fan Coil Units	Trane, UHSA-0905-BC-88E		Ground floor Loading Dock	2
26	1	ERV #12	Munters, PV-MZP 8715-PVE		Roof	12
27	1	ERV #13	Munters, PV-MZP 8715-PVE		Roof	12
28	1	ERV #14	Munters, PV-MZP 8715-PVE		Roof	12
29	1	ERV #15	Munters, PV-MZP 8715-PVE		Roof	12
30	1	Exhaust fan EF16	Greenheck SWB-36-100	9280134	Roof	6
31	1	Exhaust fan EF17	Power Ventilator, 44x95		Roof	6
32	1	Exhaust fan EF18	Greenheck, CUBC-HP-300-20X	92801320	Roof	6
33	1	Exhaust fan EF19	Greenheck CUBC-HP-180-10X	92801318	Roof	6
34	1	Exhaust fan EF20	Greenheck 850-200-15	92D013012	Ground floor mech room	6
35	1	Exhaust Fan for elevator machine	Greenheck, SDF 8 24-D/EX	94810887	13th floor elevator machine room	6
36	1	Electrical Heater EH-1	Indeeco GUA 00800 012 000X010 000	N/A	Parking Level 1 Zone A	1
37	1	Electrical Heater EH-2	Indeeco GUA 00800 012 000X010 000	N/A	Parking Level 2 Zone A	1
38	1	Electrical Heater EH-3	Indeeco GUA 00800 012 000X010 000	N/A	Elevator machine rm Pent house	1
39	2	Cooling towers 1 & 2	Evapco LSTA 8-187	917926LHRH	Roof	4
40	5	Pressurizing fans for stairs	Greenheck 30BISW-10-CW-BH-I	1	Roof	6
41	2	Condenser Water pumps P1 & P2	Taco FM5010 98BEMD Taco FM5010-9.8	N/A	Parking Level Mech Room	4
42	4	Chiller Water pumps P3 to P6	Taco, TA15248-8	B2L172EO/ ??	Parking Level Mech Room	4
43	3	Hot Water Circulating pumps P7 to P9	Taco, FM30088.4B2H1C2LO	N/A	Parking Level Mech Room	4
44	8	Electric Unit Heater	Trane	2 Need to be added into your existing list	Various locations	1
45	4	Cabinet Unit Heaters	LD16A002W		Stairwells	1

				ALL INSTALLED AT 3/4TH FLOOR VACANT AREA FOR HEATING THE SPACE	P-1-005, P1-004, 2 IN ELECT SWITCH GEAR, P1-001, P1-ELV MACHINE RM. P1-007, P1-006	
46	16	HW Coil Heating Units	TRANE UNITS-UHSA-0205-2C-AAA			1
47	2	Air Compressor AC1 & AC2	Quincy MOC05020DA	5096735	Ground floor Mech room (24/7 Operation)	2
48	1	Air Compressor for Dry pipe system	General Cat#34466	621203	Ground floor mech room	1
49	1	Air Compressor for bladder tank	Air Compressor Products C65-7520DP	0695-4961	Parking Level Mech Room	1
50	1	GSF-1	Greenheck B5Q300 75	N/A	Garage level	6
51	1	GSF-2	Greenheck B5Q300 75	N/A	Garage level	6
52	4	Booster pumps BP 1-4	Syncroflow 30-7.5, 3J-7.5, 3J-20	910974-1 1000GPM 910974-2 400GPM, 910974-3 400GPM, 91097404	Ground Level Mech room	4
53	1	Exhaust Fan #21	Greenheck	N/A	Roof	6
54	1	Exhaust Fan #22	DX-168	N/A	Roof	6
55	1	Exhaust Fan #23	Dayton 4YY16A	12839960 1205	Roof	6
56	1	Exhaust Fan #24	Greenheck B5Q240-20	92801304	Parking Level	6
57	1	Exhaust Fan #25	Greenheck, SPBE-CA24-620-7A	92801332	Parking Level Electric Gear RM	6
58	1	Exhaust Fan #26	Greenheck, SPBE-CA24-620-7A	92801332	Parking Level Electric Gear RM	6
59	1	Exhaust Fan #27	Greenheck 850-90-7	92801371	6th floor mech room	6
60	1	Exhaust Fan #28	Greenheck 850-90-7	92801310	8th floor mech room	6
61	1	Exhaust Fan #29	Greenheck 8 50 90-2	92801311	10th floor mech room	6
62	1	Exhaust Fan #30	Greenheck B50-90-7	92801312	12th floor mech room	6
63	1	Exhaust Fan #31	463131 1/40 HP		Bulk Storge Parking Level	4
64	1	Exhaust Fan #32	463131 1/40 HP		Dead Files RM Parking level	4
65	1	Exhaust Fan #33	463131 1/40 HP		Parking Level	4
66	1	Exhaust Fan #35	SDP-20-21C	92501330	Pent House Elev. Machine room	6
67	1	Booster Fan BF-1	N/A		Level 2	4
68	1	Exhaust Fan #36	463B1 1/40 HP		Storage RM Parking Level 1	4
69	1	Exhaust Fan #37	Greenheck BSQ-90-70	92801309	4th floor mech room	6
70	1	Exhaust Fan #38	MSDF-8.24	921301321	Parking Level 2 Gas Meter RM	6
71	1	Exhaust Fan #39	463B1 1/40 HP		Storage Parking Level 2	4
72	1	Exhaust Fan #40	REMOVED OUT		Security Room 4007	6
73	1	In line fan CF-1	Greenheck, BCF-TH-106-4	92801298	Parking Level-Elev lobby	4
74	1	In line fan CF-2	Greenheck, 8CF-TH-106-4	928801299	Parking Level-Elev lobby	4
75	1	Split A/C Unit for 11A Security Tower	4029005 T		11th floor-11A Security room	6
76	1	Split A/C Unit for ASAP RM	CARRIER FM4NF060	2896A26832	1st Floor - store front Office	6
77	2	ACC1 & ACC2	Trane, 2TTA0036A40000AA			
78	2	ACU-1 and ACU-2	American Standard, TTA036A400B0	4444XG3F	Parking Level 1-Telephone rm	6
79	1	Fan	Greenheck B5Q240-20	92801304	N/A	6
80	1	Exhaust Fan	SQ-95-G	92B10335	EF-42 Kitchen Storage	4
81	2	Condenser Opened Loop Water Pumps	Baldor Reliance	VEJMM3116T	4th floor mech room - for IT Room	6
82	2	chilled water circulating pumps	Baldor Reliance	VEJMM3116T	4th floor mech room - for IT Room	6
83	2	CRAC Units (in row)	Alfa Laval		4th floor mech room - for IT Room	6
84	2	In row units	Vertiv		4th IT Room.	6
85	1	VAV box	Trane		4th floor mech room - for IT Room	3
TRADES CENTER PARKING GARAGE 2881 S. TAYLOR ST.						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Electric unit heater	FIFVH	3003	SPRINKLER ROOM	1
VEHICLE WASH STATION 4260 S. 28TH ST.						
NO.	QTY	EQUIPMENT TYPE	MANUFACTURER/MODEL NO.	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
1	1	Heat Pump	A42HC09K	XXEXA60	Break room	4
2	2	Box Heater	N/A	N/A		2

DEPT. OF HUMAN SERVICES, SEQUOIA PLAZA I, II, & III 2100 WASHINGTON BLVD						
NO.	QTY	EQUIPMENT TYPE	MODEL	SERIAL NO.	LOCATION/REMARKS	INSPECTION #S
Sequoia Plaza II						
1	1	Ductless Split Air Conditioning	OHS-24-HG-FC	TBD	AC-B3	9
2	1	Ductless Split Air Conditioning	OHS-40-HG-FC	TBD	AC-1A	9
3	1	Ductless Split Air Conditioning	OHS-24-HG-FC	TBD	AC-1B	9
4	1	Ductless Split Air Conditioning	OHS-24-HG-FC	TBD	AC-2A	9
5	1	Ductless Split Air Conditioning	OHS-40-HG-FC	TBD	AC-2B	9
6	1	Ductless Split Air Conditioning	OHS-24-HG-FC	TBD	AC-3A	9
7	1	Ductless Split Air Conditioning	OHS-40-HG-FC	TBD	AC-3B	9
8	1	Ductless Split Air Conditioning	OHS-24-HG-FC	TBD	AC-4A	9
9	1	Ductless Split Air Conditioning	OHS-40-HG-FC	TBD	AC-46	9
10	1	Ductless Split Air Conditioning	TBD	TBD		9
11	1	Ductless Split Air Conditioning	ACG-180-4HGO	TBD	AC-B2	9
12	1	Ductless Split Air Conditioning	ECO	TBD	AC-B3	9
13	1	Ductless Split Air Conditioning	ECO	TBD	AC-C1	9
Sequoia Plaza II						
14	1	Air Handler	MMD12E7PH	Y15BB17093	3rd floor	9
15	1	Condenser	PFH014A-PL7	Y15BG16100	3rd floor	9
Sequoia Plaza III						
16	1	Air Handler	MMD12E7PH	Y157B171	4th floor	9
17	1	Condenser	PFH014A-PL7	Y15BG16095	4th floor	9
18	1	Air Handler	MMD12E7PH	Y15BB17091	3rd floor	9
19	1	Condenser	PFH014A-PL7	Y15BG16098	3rd floor	9
20	1	Air Handler	MMD12E7PH	Y15BB17092	2nd floor	9
21	1	Condenser	PFH014A-PL7	Y15BG16097	2nd floor	9
22	1	Air Handler	MMD12E7PH	Y15BB170904	1st floor	9
23	1	Condenser	PFH014A-PL7	Y15CG16102	1st floor	9
24	1	Air Handler	A1-E-354-G10	TBD	Outside air	9
Dept. of Human Services						
25	1	Exhaust Fans	135 ACRU 135	143SF65608-00		9
26	1	Exhaust Fans	135 ACRU 135	143SF65608-00		9
27	1	Exhaust Fans	135 ACRU 135	TBD		9
28	1	Exhaust Fans	135 ACRU 135	TBD		9
29	1	Exhaust Fans	RN-008-3-0-E799	201503-ANCH09373	Rooftop	9
30	1	Exhaust Fans	DBS010AHCE4DW	EBOU150301086	Rooftop	9

LONG BRIDGE AQUATICS & FITNESS CENTER 333 LONG BRIDGE DRIVE						
1	1	Air Handler Unit AHU #1	TBD	TBD	Office/lobby	3
2	1	Air Handler Unit AHU #2	TBD	TBD	Fitness Area	3
3	1	Air Handler Unit AHU #3	TBD	TBD	Spectator Area	3
4	1	Air Unit DOAS-1	TBD	TBD	Lockers/Wet Class	3
5	1	Trane UHEC Unit heaters -1	TBD	TBD		3
6	1	Trane UHEC Unit heaters -2	TBD	TBD		3
7	1	Trane UHEC Unit heaters -3	TBD	TBD		3
8	1	Trane UHEC Unit heaters -4	TBD	TBD		3
9	1	Trane UHEC Unit heaters -5	TBD	TBD		3
10	1	Trane UHEC Unit heaters -6	TBD	TBD		3
11	1	Trane UHEC Unit heaters -7	TBD	TBD		3
12	1	Trane UHEC Unit heaters -8	TBD	TBD		3
13	1	Trane UHEC Unit heaters -9	TBD	TBD		3
14	1	Trane UHEC Unit heaters -10	TBD	TBD		3
15	1	Trane UHEC Unit heaters -11	TBD	TBD		3
16	1	Trane UHEC Unit heaters -12	TBD	TBD		3
17	1	King KBS Unit heaters -13	TBD	TBD		3
18	1	King KBS Unit heaters -14	TBD	TBD		3
19	1	Armstrong Pump-1	TBD	TBD		3
20	1	Armstrong Pump-2	TBD	TBD		3
21	1	Armstrong Pump-3	TBD	TBD		3
22	1	Armstrong Pump-4	TBD	TBD		3
23	1	Armstrong Pump-5	TBD	TBD		3
24	1	Armstrong Pump-6	TBD	TBD		3
25	1	Armstrong Pump-7.1	TBD	TBD		3
26	1	Armstrong Pump-7.2	TBD	TBD		3
27	1	Armstrong Pump-8	TBD	TBD		3
28	1	Armstrong Pump-9	TBD	TBD		3
29	1	Armstrong Pump-10	TBD	TBD		3
30	1	Cabinet Unit Heaters CUH - 1	TBD	TBD		3
31	1	Cabinet Unit Heaters CUH - 2	TBD	TBD		3
34	1	Electric Wall Heaters EWH - 1	TBD	TBD		3
35	1	Electric Wall Heaters EWH - 2	TBD	TBD		3
36	1	Electrical Baseboard Heater EBB - 1	TBD	TBD		3
37	1	Electrical Baseboard Heater EBB - 3	TBD	TBD		3
38	1	Hot Water Boiler B-1	TBD	TBD		3
39	1	Hot Water Boiler B-2	TBD	TBD		3
40	1	Hot Water Boiler B-3	TBD	TBD		3
41	1	Hot Water Boiler B-4	TBD	TBD		3
42	1	Expansion Tank ET-1	TBD	TBD		3
43	1	Expansion Tank ET-2	TBD	TBD		3

44	1	Air Separator JASR-1	TBD	TBD		3
45	1	Air Separator JASR-2	TBD	TBD		3
46	1	Liquid to Liquid Heat Exchanger HEX-1	TBD	TBD		3
47	1	Dry Coolers Direct Coil DC-1	FC09AW7D278T4	TBD		3
48	1	Dry Coolers Direct Coil DC-2	FC09AW7D151T4	TBD		3
49	1	Ductless Split Air Conditioning Mitsubishi AC-1	PUMY-P36NKMU1	TBD		3
50	1	Ductless Split Air Conditioning Daikin AC-2	FBQ18PVJU-RZR18	TBD		3
51	1	Ductless Split Air Conditioning Mitsubishi AC-3	PUMY-P36NKMU3	TBD		3
52	1	Fans Lorem Cook EF-1	150SQN17D (VF)	TBD		3
53	1	Fans Lorem Cook EF-2	90SQN10D	TBD		3
54	1	Fans Lorem Cook EF-3	FANTECH FR 140	TBD		3
55	1	Fans Lorem Cook EF-4	FANTECH FR 140	TBD		3
56	1	Fans Lorem Cook EF-5	FANTECH FR 140	TBD		3
57	1	Fans Lorem Cook EF-6	FANTECH FR 140	TBD		3
58	1	Fans Lorem Cook EF-7	18XP24D17EC	TBD		3
59	1	Fans Lorem Cook EF-8	18XP29D17EC	TBD		3
60	1	Fans Lorem Cook EF-9	150SQN17D	TBD		3
61	1	Fans Lorem Cook EF-10	12XP26D17EC	TBD		3
62	1	Fans Lorem Cook EF-11	150SQN17D	TBD		3
63	1	Fans Lorem Cook EF-12	245 CPS-A	TBD		3
64	1	Fans Lorem Cook EF-13	255 CPS-A	TBD		3
65	1	Fans Lorem Cook EF-14	150SQN17D (VF)	TBD		3
66	1	Fans Lorem Cook EF-15	FANTECH DBF 110	TBD		3
67	1	Fans Lorem Cook EF-16	300SQN-B	TBD		3
68	1	VAV - Variable Air Volume Units VAV-1-1	TBD	TBD		3
69	1	VAV - Variable Air Volume Units VAV-1-2	TBD	TBD		3
70	1	VAV - Variable Air Volume Units VAV-1-3	TBD	TBD		3
71	1	VAV - Variable Air Volume Units VAV-1-4	TBD	TBD		3
72	1	VAV - Variable Air Volume Units VAV-1-5	TBD	TBD		3
73	1	VAV - Variable Air Volume Units VAV-1-6	TBD	TBD		3
74	1	VAV - Variable Air Volume Units VAV-1-7	TBD	TBD		3
75	1	VAV - Variable Air Volume Units VAV-1-8	TBD	TBD		3
76	1	VAV - Variable Air Volume Units VAV-1-9	TBD	TBD		3
77	1	VAV - Variable Air Volume Units VAV-1-10	TBD	TBD		3
78	1	VAV - Variable Air Volume Units VAV-2-1	TBD	TBD		3
79	1	VAV - Variable Air Volume Units VAV-2-2	TBD	TBD		3
80	1	VAV - Variable Air Volume Units VAV-2-3	TBD	TBD		3
81	1	Glycol Makeup Units Armstrong GMU-1	GLA-S-HP-1	TBD		3
82	1	Glycol Makeup Units Armstrong GMU-2	GLA-S-HP-2	TBD		3
ARLINGTON ECONOMIC DEVELOPMENT 110 N. GLEBE ROAD						
1	1	Heat Pump	Stultz FCS-024-W	1298010	K1	4
1	2	Heat Pump	FHP EM120-4VTC	HK28594	M1	4